

# EDAN Agile PLM Electronic Signature Information

--Signatures related to this document and performed in EDAN Agile PLM.

文件名称(Document Name) : Acclarix AX3 系列使用说明书高级册\_英文

文件编号(Number) : 01.54.458118

版本(Version) : 1.1

产品型号(Product Model) : Acclarix AX3

项目编码(Project Code) : 00001G001

## 签批信息(Signature):

作者(Originator) : 谢菊艳 (xiejuyan) 2019-06-10 11:58:18

审核人(Reviewers) : 陈云飞 (chenyunfei) 2019-06-11 15:51:04

审核人(Reviewers) : 唐青松 (tangqingsong) 2019-06-10 15:43:38

审核人(Reviewers) : 郭雪梅 (guoxuemei) 2019-06-10 17:23:23

审核人(Reviewers) : 郭欣 (guoxin) 2019-06-11 08:45:22

审核人(Reviewers) : 李姣 (lijiao) 2019-06-10 14:14:54

审核人(Reviewers) : 明镭 (minglei) 2019-06-10 14:18:56

审核人(Reviewers) : 冯丹 (fengdan) 2019-06-11 09:32:34

批准人(Approvers) : 郭伟娟 (guoweijuan) 2019-06-11 16:25:13

批准人(Approvers) : 冀伟 (jiwei) 2019-06-11 16:42:41

# Acclarix AX3 Series

Diagnostic Ultrasound System

Version 1.1

## User Manual

Advanced Volume

CE<sub>0123</sub>



# Preface

P/N:01.54.458118

MPN: 01.54.458118011

Release Date: May, 2019

© Copyright EDAN INSTRUMENTS, INC. 2018-2019

This User Manual applies to 1.0X releases for Acclarix AX3 series Diagnostic Ultrasound Systems including Acclarix AX3, Acclarix AX3 Exp, Acclarix AX3 Super, Acclarix AX25, Acclarix AX28, Acclarix AX2, Acclarix AX2 Exp, Acclarix AX2 Super, Acclarix AX15 and Acclarix AX18. See Section A.9 in the basic user manual for the difference between these models.

This User Manual Advanced Volume together with the User Manual Basic Volume (P/N: 01.54.458117) contains necessary and sufficient information to use the Acclarix AX3 Series Diagnostic Ultrasound Systems safely for the intended purposes and approved clinical applications.

Not all measurements and features are available for all system models with different transducers. This manual is based on the maximum configuration and therefore some contents may not apply to your product. If you have any question, please contact EDAN.

## Contact Information:

For sales or service information please contact your local distributor or the EDAN service department at: [support@edan.com.cn](mailto:support@edan.com.cn)

## Regulatory Approval Remarks

- The transducer L17-7HQ may not be available at the time of release of this user manual. Consult your local representatives for the availability of this feature.

# Content

|          |   |           |
|----------|---|-----------|
| <b>1</b> | <b>Acoustic Output Data</b> .....                         | <b>1</b>  |
| 1.1.     | Acoustic Output Table for C5-2Q .....                     | 3         |
| 1.2.     | Acoustic Output Table for L12-5Q .....                    | 7         |
| 1.3.     | Acoustic Output Table for L17-7Q .....                    | 11        |
| 1.4.     | Acoustic Output Table for P5-1Q.....                      | 15        |
| 1.5.     | Acoustic Output Table for E8-4Q.....                      | 20        |
| 1.6.     | Acoustic Output Table for L17-7HQ.....                    | 24        |
| <b>2</b> | <b>Maximum Transducer Surface Temperature</b> .....       | <b>28</b> |
| <b>3</b> | <b>Formulas</b> .....                                     | <b>29</b> |
| <b>4</b> | <b>Obstetrical References</b> .....                       | <b>35</b> |
| 4.1.     | Application Table of Obstetrical Reference Formulas ..... | 35        |
| 4.2.     | GS .....  | 36        |
| 4.3.     | CRL .....   | 38        |
| 4.4.     | BPD .....   | 40        |
| 4.5.     | HC .....  | 44        |
| 4.6.     | AC .....  | 45        |
| 4.7.     | FL.....   | 46        |
| 4.8.     | FTA.....  | 49        |
| 4.9.     | HUM .....   | 50        |
| 4.10.    | CER.....  | 51        |
| 4.11.    | THD .....   | 51        |
| 4.12.    | Estimated Fetal Weight.....                               | 51        |

# 1 Acoustic Output Data

Table 1-1 Table Key

| Abbreviation               | Full Name  |
|----------------------------|--|
| $A_{\text{aprt}}$          | -12dB Output Beam Area                             |
| $d_{\text{eq}}$            | Equivalent Beam Diameter                           |
| $f_{\text{awf}}$           | Acoustic Working Frequency                         |
| $I_{\text{pa}, \alpha}$    | Attenuated Pulse-Average Intensity                 |
| $pii$                      | Pulse-Intensity Integral                           |
| $pii_{\alpha}$             | Attenuated Pulse-Intensity Integral                |
| $I_{\text{sppa}, \alpha}$  | Attenuated Spatial-Peak Pulse-Average Intensity    |
| $I_{\text{spta}}$          | Spatial-Peak Temporal-Average Intensity            |
| $I_{\text{spta}, \alpha}$  | Attenuated Spatial-Peak Temporal-Average Intensity |
| $I_{\text{ta}, \alpha}(Z)$ | Attenuated Temporal-Average Intensity              |
| $MI$                       | Mechanical Index                                   |
| $P$                        | Output Power                                       |
| $P_{\alpha}$               | Attenuated Output Power                            |
| $P_{r, \alpha}$            | Attenuated Peak-Rarefactional Acoustic Pressure    |
| $P_r$                      | Peak-Rarefactional Acoustic Pressure               |
| $n_{\text{pps}}$           | Number of Pulse per Ultrasonic Scan Line           |
| $pr$                       | Pulse Repetition Rate                              |
| $srr$                      | Scan Repetition Rate                               |
| $TI$                       | Thermal Index                                      |
| $TIB$                      | Bone Thermal Index                                 |
| $TIC$                      | Cranial-Bone Thermal Index                         |
| $TIS$                      | Soft-Tissue Thermal Index                          |
| $t_d$                      | Pulse Duration                                     |
| $X, Y$                     | -12dB Output Beam Dimensions                       |
| $z_b$                      | Depth for Bone Thermal Index                       |
| $z_{\text{bp}}$            | Break-Point Depth                                  |
| $z_{\text{pii}}$           | Depth for Peak Pulse-Intensity Integral            |
| $z_{MI}$                   | Depth for Mechanical Index                         |
| $z_{\text{pii}, \alpha}$   | Depth for Peak Attenuated Pulse Intensity Integral |

|                  |  |
|------------------|--|
| $Z_{sii}$        | Depth for Peak Sum of pulse intensity intergrals           |
| $Z_{sii,\alpha}$ | Depth for peak sum of attenuated pulse intensity integrals |
| $Z_s$            | Depth for TIS  |
| FOV              | Field of View  |
| PRF              | Pulse Repetition Frequency                                 |
| SV               | Sample Volume  |

### 1.1. Acoustic Output Table for C5-2Q

Acoustic Output Reporting Table for IEC60601-2-37

Transducer Model: C5-2Q

Operating Mode: B

| Index label                    |  | MI                    | TIS        |               | TIB        |               | TIC  |     |
|--------------------------------|--|-----------------------|------------|---------------|------------|---------------|------|-----|
|                                |  |                       | At surface | Below surface | At surface | Below surface |      |     |
| Maximum index value            |  | 1.16                  | 1.37       |               | 1.37       |               | N/A  |     |
| Index Component Value          |  |                       | 1.37       | 1.37          | 1.37       | 1.37          |      |     |
| Associated acoustic parameters | $p_{r,\alpha}$ at $z_{MI}$                 | (MPa)                 | 1.80       |               |            |               |      |     |
|                                | $P$  | (mW)                  |            | 128.55        | 128.55     |               | N/A  |     |
|                                | $P_{1x1}$                                  | (mW)                  |            | 98.88         | 98.88      |               |      |     |
|                                | $z_s$                                      | (cm)                  |            |               | -          |               |      |     |
|                                | $z_b$                                      | (cm)                  |            |               |            | -             |      |     |
|                                | $z_{MI}$                                   | (cm)                  | 0.95       |               |            |               |      |     |
|                                | $z_{PII,a}$                                | (cm)                  | 0.95       |               |            |               |      |     |
|                                | $f_{awf}$                                  | (MHz)                 | 2.42       | 2.41          | 2.41       | 2.41          | 2.41 | N/A |
| Other Information              | $p_{rr}$                                   | (Hz)                  | -          |               |            |               |      |     |
|                                | $S_{rr}$                                   | (Hz)                  | 53.00      |               |            |               |      |     |
|                                | $n_{pps}$                                  |                       | 1.00       |               |            |               |      |     |
|                                | $I_{pa,\alpha}$ at $z_{PII,a}$             | (W/cm <sup>2</sup> )  | 94.85      |               |            |               |      |     |
|                                | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 12.02      |               |            |               |      |     |
|                                | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 9.64       |               |            |               |      |     |
|                                | $pr$ at $z_{PII}$                          | (MPa)                 | 1.69       |               |            |               |      |     |
| Operating control conditions   | B Frequency                                |                       | Level H1   | Level H1      | Level H1   |               | N/A  |     |
|                                | B Display Depth(mm)                        |                       | 40.00      | 40.00         | 40.00      |               | N/A  |     |
|                                | B Focus Pos(mm)                            |                       | 30.00      | 30.00         | 30.00      |               | N/A  |     |
|                                | B FOV                                      |                       | Small      | Small         | Small      |               | N/A  |     |
|                                | B Line Density                             |                       | Low        | Low           | Low        |               | N/A  |     |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.

**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: C5-2Q

Operating Mode: B+M

| Index label                    |  | MI                    | TIS        |               | TIB        |               | TIC  |     |
|--------------------------------|--|-----------------------|------------|---------------|------------|---------------|------|-----|
|                                |  |                       | At surface | Below surface | At surface | Below surface |      |     |
| Maximum index value            |  | 1.21                  | 1.11       |               | 1.63       |               | N/A  |     |
| Index Component Value          |  |                       | 1.04       | 1.11          | 1.04       | 1.63          |      |     |
| Associated acoustic parameters | $p_{r,\alpha}$ at $z_{MI}$                 | (MPa)                 | 2.08       |               |            |               |      |     |
|                                | $P$  | (mW)                  |            | 96.06         | 96.06      |               | N/A  |     |
|                                | $P_{1 \times 1}$                           | (mW)                  |            | 73.89         | 73.89      |               |      |     |
|                                | $z_s$                                      | (cm)                  |            |               | 0.30       |               |      |     |
|                                | $z_b$                                      | (cm)                  |            |               |            | 1.66          |      |     |
|                                | $z_{MI}$                                   | (cm)                  | 1.76       |               |            |               |      |     |
|                                | $z_{PII,a}$                                | (cm)                  | 1.76       |               |            |               |      |     |
|                                | $f_{awf}$                                  | (MHz)                 | 2.94       | 2.98          | 2.98       | 2.98          | 2.98 | N/A |
| Other Information              | $p_{rr}$                                   | (Hz)                  | 1000.00    |               |            |               |      |     |
|                                | $S_{rr}$                                   | (Hz)                  | -          |               |            |               |      |     |
|                                | $n_{pps}$                                  |                       | 1.00       |               |            |               |      |     |
|                                | $I_{pa,\alpha}$ at $z_{PII,a}$             | (W/cm <sup>2</sup> )  | 149.06     |               |            |               |      |     |
|                                | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 62.97      |               |            |               |      |     |
|                                | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 69.76      |               |            |               |      |     |
|                                | $pr$ at $z_{PII}$                          | (MPa)                 | 2.16       |               |            |               |      |     |
| Operating control conditions   | B Frequency                                |                       | Level H1   | Level H1      |            | Level H1      |      | N/A |
|                                | B Display Depth(mm)                        |                       | 40.00      | 40.00         |            | 40.00         |      | N/A |
|                                | B Focus Pos(mm)                            |                       | 40.00      | 40.00         |            | 40.00         |      | N/A |
|                                | B FOV                                      |                       | Full       | Full          |            | Full          |      | N/A |
|                                | B Line Density                             |                       | Low        | Low           |            | Low           |      | N/A |
|                                | M Sweep Speed                              |                       | Fast       | Fast          |            | Fast          |      | N/A |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.



**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: C5-2Q

Operating Mode: B+C/B+PDI/B+DPDI

| Index label                    |                                  | MI                    | TIS        |               | TIB        |               | TIC  |
|--------------------------------|----------------------------------|-----------------------|------------|---------------|------------|---------------|------|
|                                |                                  |                       | At surface | Below surface | At surface | Below surface |      |
| Maximum index value            |                                  | 1.18                  | 1.48       |               | 1.48       |               | N/A  |
| Index Component Value          |                                  |                       | 1.48       | 1.48          | 1.48       | 1.48          |      |
| Associated acoustic parameters | $p_{r,\alpha}$ at zMI            | (MPa)                 | 2.23       |               |            |               |      |
|                                | P                                | (mW)                  |            | 133.65        | 133.65     |               | N/A  |
|                                | $P_{1X1}$                        | (mW)                  |            | 102.80        | 102.80     |               |      |
|                                | Zs                               | (cm)                  |            | -             |            |               |      |
|                                | Zb                               | (cm)                  |            |               |            | -             |      |
|                                | ZMI                              | (cm)                  | 1.46       |               |            |               |      |
|                                | ZPII,a                           | (cm)                  | 1.46       |               |            |               |      |
|                                | fawf                             | (MHz)                 | 3.56       | 2.96          | 2.96       | 2.96          | 2.96 |
| Other Information              | pr                               | (Hz)                  | -          |               |            |               |      |
|                                | Srr                              | (Hz)                  | 31.17      |               |            |               |      |
|                                | npps                             |                       | 1.00       |               |            |               |      |
|                                | $I_{pa,\alpha}$ at ZPII,a        | (W/cm <sup>2</sup> )  | 226.16     |               |            |               |      |
|                                | $I_{spta,a}$ at ZPII,a OR ZSII,a | (mW/cm <sup>2</sup> ) | 4.03       |               |            |               |      |
|                                | $I_{spta}$ at ZPII OR ZSII       | (mW/cm <sup>2</sup> ) | 2.83       |               |            |               |      |
|                                | pr at ZPII                       | (MPa)                 | 2.29       |               |            |               |      |
| Operating control conditions   | B Frequency                      | Level 2               | Level 2    | Level 2       | Level 2    |               | N/A  |
|                                | B Display Depth(mm)              | 240.00                | 240.00     | 240.00        | 240.00     |               | N/A  |
|                                | B FOV                            | Small                 | Small      | Small         | Small      |               | N/A  |
|                                | B Line Density                   | High                  | High       | High          | High       |               | N/A  |
|                                | C Frequency                      | Level 1               | Level 1    | Level 1       | Level 1    |               | N/A  |
|                                | C Left Edge of ROI(mm)           | -7.50                 | -7.50      | -7.50         | -7.50      |               | N/A  |
|                                | C Right Edge of ROI(mm)          | 7.50                  | 7.50       | 7.50          | 7.50       |               | N/A  |
|                                | C Up Edge of ROI(mm)             | 25.50                 | 25.50      | 25.50         | 25.50      |               | N/A  |
|                                | C Down Edge of ROI(mm)           | 34.50                 | 34.50      | 34.50         | 34.50      |               | N/A  |
|                                | C Line Density                   | Low                   | Low        | Low           | Low        |               | N/A  |
|                                | C PRF(KHz)                       | 0.60                  | 1.90       | 1.90          | 1.90       |               | N/A  |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.

**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: C5-2Q

Operating Mode: PW/B+PW/B+C+PW

| Index label                    |  | MI                    | TIS        |               | TIB        |               | TIC  |     |
|--------------------------------|--|-----------------------|------------|---------------|------------|---------------|------|-----|
|                                |  |                       | At surface | Below surface | At surface | Below surface |      |     |
| Maximum index value            |  | 1.22                  | 1.02       |               | 2.72       |               | N/A  |     |
| Index Component Value          |  |                       | 0.71       | 1.02          | 0.69       | 2.72          |      |     |
| Associated acoustic parameters | $p_{r,\alpha}$ at $z_{MI}$                 | (MPa)                 | 1.88       |               |            |               |      |     |
|                                | $P$  | (mW)                  |            | 100.51        | 79.56      |               | N/A  |     |
|                                | $P_{1X1}$                                  | (mW)                  |            | 50.33         |            | 61.20         |      |     |
|                                | $z_s$                                      | (cm)                  |            |               | 1.15       |               |      |     |
|                                | $z_b$                                      | (cm)                  |            |               |            | 1.10          |      |     |
|                                | $Z_{MI}$                                   | (cm)                  | 1.86       |               |            |               |      |     |
|                                | $Z_{PII,a}$                                | (cm)                  | 1.86       |               |            |               |      |     |
|                                | $f_{awf}$                                  | (MHz)                 | 2.36       | 2.96          | 2.96       | 2.36          | 2.36 | N/A |
| Other Information              | $p_{rr}$                                   | (Hz)                  | 900.00     |               |            |               |      |     |
|                                | $S_{rr}$                                   | (Hz)                  | -          |               |            |               |      |     |
|                                | $\eta_{pps}$                               |                       | 1.00       |               |            |               |      |     |
|                                | $I_{pa,\alpha}$ at $Z_{PII,a}$             | (W/cm <sup>2</sup> )  | 139.51     |               |            |               |      |     |
|                                | $I_{spta,a}$ at $Z_{PII,a}$ or $Z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 350.99     |               |            |               |      |     |
|                                | $I_{spta}$ at $Z_{PII}$ or $Z_{SII}$       | (mW/cm <sup>2</sup> ) | 428.44     |               |            |               |      |     |
|                                | $p_r$ at $Z_{PII}$                         | (MPa)                 | 1.74       |               |            |               |      |     |
| Operating control conditions   | B Frequency                                | -                     | -          | -             | -          | -             | N/A  |     |
|                                | B Display Depth(mm)                        | -                     | -          | -             | -          | -             | N/A  |     |
|                                | B Focus Pos(mm)                            | -                     | -          | -             | -          | -             | N/A  |     |
|                                | B FOV                                      | -                     | -          | -             | -          | -             | N/A  |     |
|                                | B Line Density                             | -                     | -          | -             | -          | -             | N/A  |     |
|                                | PW Frequency                               | Level 0               | Level 1    | Level 0       | Level 0    | Level 0       | N/A  |     |
|                                | PW SV Depth(mm)                            | 30.00                 | 160.00     | 30.00         | 30.00      | 30.00         | N/A  |     |
|                                | PW PRF(KHz)                                | 0.90                  | 5.90       | 0.90          | 0.90       | 0.90          | N/A  |     |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.

## 1.2. Acoustic Output Table for L12-5Q

### Acoustic Output Reporting Table for IEC60601-2-37

Transducer Model: L12-5Q

Operating Mode: B

| Index label   |  | MI                    | TIS        |               | TIB        |               | TIC  |
|---|--|-----------------------|------------|---------------|------------|---------------|------|
|   |  |                       | At surface | Below surface | At surface | Below surface |      |
| Maximum index value   |  | 1.28                  | 1.33       |               | 1.33       |               | N/A  |
| Index Component Value   |  |                       | 1.33       | 1.33          | 1.33       | 1.33          |      |
| Associated acoustic parameters  | $p_{r,\alpha}$ at $z_{MI}$                 | (MPa)                 | 2.98       |               |            |               |      |
|   | P  | (mW)                  |            | 51.52         | 51.52      |               | N/A  |
|   | $P_{1 \times 1}$                           | (mW)                  |            | 51.52         | 51.52      |               |      |
|   | $z_s$                                      | (cm)                  |            | -             |            |               |      |
|   | $z_b$                                      | (cm)                  |            |               |            | -             |      |
|   | $z_{MI}$                                   | (cm)                  | 0.81       |               |            |               |      |
|   | $z_{PII,a}$                                | (cm)                  | 0.81       |               |            |               |      |
|   | $f_{awf}$                                  | (MHz)                 | 5.38       | 5.44          | 5.44       | 5.44          | 5.44 |
| Other Information   | pr   | (Hz)                  | -          |               |            |               |      |
|   | Srr  | (Hz)                  | 114.00     |               |            |               |      |
|   | npps                                       |                       | 1.00       |               |            |               |      |
|   | $I_{pa,\alpha}$ at $z_{PII,a}$             | (W/cm <sup>2</sup> )  | 342.55     |               |            |               |      |
|   | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 20.48      |               |            |               |      |
|   | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 20.91      |               |            |               |      |
|   | pr at $z_{PII}$                            | (MPa)                 | 3.44       |               |            |               |      |
| Operating control conditions  | B Frequency                                | Level H1              | Level 0    |               | Level 0    |               | N/A  |
|   | B Display Depth(mm)                        | 10.00                 | 110.00     |               | 110.00     |               | N/A  |
|   | B Focus Pos(mm)                            | 7.50                  | 45.00      |               | 45.00      |               | N/A  |
|   | B FOV                                      | Small                 | Full       |               | Full       |               | N/A  |
|   | B Line Density                             | Low                   | Low        |               | Low        |               | N/A  |
| Note:   |  |                       |            |               |            |               |      |
| 1. (-) This index or parameter is not required for this operating mode. |  |                       |            |               |            |               |      |
| 2. (N/A) This transducer is not intended for cephalic examination.      |  |                       |            |               |            |               |      |

**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: L12-5Q

Operating Mode: B+M

| Index label                    |  |                       | MI       | TIS        |               | TIB        |               | TIC |
|--------------------------------|--|-----------------------|----------|------------|---------------|------------|---------------|-----|
|                                |  |                       |          | At surface | Below surface | At surface | Below surface |     |
| Maximum index value            |  |                       | 1.38     | 0.70       |               | 0.91       |               | N/A |
| Index Component Value          |  |                       |          | 0.70       | 0.67          | 0.70       | 0.91          |     |
| Associated acoustic parameters | $p_{r,\alpha}$ at zMI                      | (MPa)                 | 3.18     |            |               |            |               |     |
|                                | P  | (mW)                  |          | 26.56      |               | 26.56      |               | N/A |
|                                | $P_{1 \times 1}$                           | (mW)                  |          | 26.56      |               | 26.56      |               |     |
|                                | $z_s$                                      | (cm)                  |          |            | 0.35          |            |               |     |
|                                | $z_b$                                      | (cm)                  |          |            |               |            | 1.01          |     |
|                                | $z_{MI}$                                   | (cm)                  | 0.76     |            |               |            |               |     |
|                                | $z_{PII,a}$                                | (cm)                  | 0.76     |            |               |            |               |     |
| Other Information              | $f_{awf}$                                  | (MHz)                 | 5.33     | 5.52       | 5.52          | 5.52       | 5.52          | N/A |
|                                | pr   | (Hz)                  | 1000.00  |            |               |            |               |     |
|                                | Srr  | (Hz)                  | -        |            |               |            |               |     |
|                                | npps                                       |                       | 1.00     |            |               |            |               |     |
|                                | $I_{pa,\alpha}$ at $z_{PII,a}$             | (W/cm <sup>2</sup> )  | 377.86   |            |               |            |               |     |
|                                | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 88.91    |            |               |            |               |     |
|                                | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 119.79   |            |               |            |               |     |
| pr at $z_{PII}$                | (MPa)                                      | 3.59                  |          |            |               |            |               |     |
| Operating control conditions   | B Frequency                                |                       | Level H0 | Level 0    |               | Level 0    |               | N/A |
|                                | B Display Depth(mm)                        |                       | 10.00    | 110.00     |               | 110.00     |               | N/A |
|                                | B Focus Pos(mm)                            |                       | 7.50     | 45.00      |               | 45.00      |               | N/A |
|                                | B FOV                                      |                       | Small    | Small      |               | Small      |               | N/A |
|                                | B Line Density                             |                       | Low      | Low        |               | Low        |               | N/A |
|                                | M Sweep Speed                              |                       | Slow     | Fast       |               | Fast       |               | N/A |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.

**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: L12-5Q

Operating Mode: B+C/B+PDI/B+DPDI

| Index label                    |  |                       | MI      | TIS        |               | TIB        |               | TIC |
|--------------------------------|--|-----------------------|---------|------------|---------------|------------|---------------|-----|
|                                |  |                       |         | At surface | Below surface | At surface | Below surface |     |
| Maximum index value            |  |                       | 1.16    | 0.80       |               | 0.80       |               | N/A |
| Index Component Value          |  |                       |         | 0.80       | 0.80          | 0.80       | 0.80          |     |
| Associated acoustic parameters | $p_{r,\alpha}$ at zMI                      | (MPa)                 | 2.71    |            |               |            |               |     |
|                                | P  | (mW)                  |         | 31.42      |               | 31.42      |               | N/A |
|                                | $P_{1 \times 1}$                           | (mW)                  |         | 31.42      |               | 31.42      |               |     |
|                                | $z_s$                                      | (cm)                  |         |            | -             |            |               |     |
|                                | $z_b$                                      | (cm)                  |         |            |               |            | -             |     |
|                                | $z_{MI}$                                   | (cm)                  | 1.11    |            |               |            |               |     |
|                                | $z_{PII,a}$                                | (cm)                  | 1.11    |            |               |            |               |     |
|                                | $f_{awf}$                                  | (MHz)                 | 5.46    | 5.36       | 5.36          | 5.36       | 5.36          | N/A |
| Other Information              | pr   | (Hz)                  | -       |            |               |            |               |     |
|                                | Srr  | (Hz)                  | 29.23   |            |               |            |               |     |
|                                | npps                                       |                       | 1.00    |            |               |            |               |     |
|                                | $I_{pa,\alpha}$ at $z_{PII,a}$             | (W/cm <sup>2</sup> )  | 299.85  |            |               |            |               |     |
|                                | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 15.64   |            |               |            |               |     |
|                                | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 15.83   |            |               |            |               |     |
|                                | pr at $z_{PII}$                            | (MPa)                 | 3.36    |            |               |            |               |     |
| Operating control conditions   | B Frequency                                |                       | Level 0 | Level 0    |               | Level 0    |               | N/A |
|                                | B Display Depth(mm)                        |                       | 110.00  | 110.00     |               | 110.00     |               | N/A |
|                                | B FOV                                      |                       | Small   | Small      |               | Small      |               | N/A |
|                                | B Line Density                             |                       | High    | High       |               | High       |               | N/A |
|                                | C Frequency                                |                       | Level 0 | Level 0    |               | Level 0    |               | N/A |
|                                | C Left Edge of ROI(mm)                     |                       | -4.75   | -4.75      |               | -4.75      |               | N/A |
|                                | C Right Edge of ROI(mm)                    |                       | 4.75    | 4.75       |               | 4.75       |               | N/A |
|                                | C Up Edge of ROI(mm)                       |                       | 40.50   | 40.50      |               | 40.50      |               | N/A |
|                                | C Down Edge of ROI(mm)                     |                       | 49.50   | 49.50      |               | 49.50      |               | N/A |
|                                | C Line Density                             |                       | Low     | Low        |               | Low        |               | N/A |
|                                | C PRF(KHz)                                 |                       | 6.10    | 6.10       |               | 6.10       |               | N/A |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.

**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: L12-5Q

Operating Mode: PW/B+PW/B+C+PW

| Index label                    |  |                       | MI       | TIS        |               | TIB        |               | TIC |
|--------------------------------|--|-----------------------|----------|------------|---------------|------------|---------------|-----|
|                                |  |                       |          | At surface | Below surface | At surface | Below surface |     |
| Maximum index value            |  |                       | 1.48     | 0.54       |               | 1.27       |               | N/A |
| Index Component Value          |  |                       |          | 0.49       | 0.54          | 0.26       | 1.27          |     |
| Associated acoustic parameters | $p_{r,\alpha}$ at zMI                      | (MPa)                 | 3.21     |            |               |            |               |     |
|                                | P  | (mW)                  |          | 25.56      |               | 11.55      |               | N/A |
|                                | $P_{1x1}$                                  | (mW)                  |          | 21.06      |               | 11.55      |               |     |
|                                | $z_s$                                      | (cm)                  |          |            | 0.30          |            |               |     |
|                                | $z_b$                                      | (cm)                  |          |            |               |            | 0.71          |     |
|                                | $z_{MI}$                                   | (cm)                  | 0.96     |            |               |            |               |     |
|                                | $z_{PII,a}$                                | (cm)                  | 0.96     |            |               |            |               |     |
| Other Information              | $f_{awf}$                                  | (MHz)                 | 4.70     | 4.72       | 4.72          | 4.70       | 4.70          | N/A |
|                                | prr  | (Hz)                  | 426.30   |            |               |            |               |     |
|                                | Srr  | (Hz)                  | -        |            |               |            |               |     |
|                                | npps                                       |                       | 1.00     |            |               |            |               |     |
|                                | $I_{pa,\alpha}$ at $z_{PII,a}$             | (W/cm <sup>2</sup> )  | 530.22   |            |               |            |               |     |
|                                | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 176.80   |            |               |            |               |     |
|                                | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 245.64   |            |               |            |               |     |
| pr at $z_{PII}$                | (MPa)                                      | 3.59                  |          |            |               |            |               |     |
| Operating control conditions   | B Frequency                                |                       | Level H0 | Level 0    |               | -          |               | N/A |
|                                | B Display Depth(mm)                        |                       | 35.00    | 55.00      |               | -          |               | N/A |
|                                | B Focus Pos(mm)                            |                       | 30.00    | 50.00      |               | -          |               | N/A |
|                                | B FOV                                      |                       | Small    | Small      |               | -          |               | N/A |
|                                | B Line Density                             |                       | Low      | Low        |               | -          |               | N/A |
|                                | PW Frequency                               |                       | Level 0  | Level 1    |               | Level 0    |               | N/A |
|                                | PW SV Depth(mm)                            |                       | 30.00    | 50.00      |               | 12.50      |               | N/A |
|                                | PW PRF(KHz)                                |                       | 0.90     | 9.80       |               | 0.90       |               | N/A |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.

### 1.3. Acoustic Output Table for L17-7Q

#### Acoustic Output Reporting Table for IEC60601-2-37

Transducer Model: L17-7Q

Operating Mode: B

| Index label                    |  | MI                    | TIS        |               | TIB        |               | TIC  |     |
|--------------------------------|--|-----------------------|------------|---------------|------------|---------------|------|-----|
|                                |  |                       | At surface | Below surface | At surface | Below surface |      |     |
| Maximum index value            |  | 1.12                  | 0.67       |               | 0.67       |               | N/A  |     |
| Index Component Value          |  |                       | 0.67       | 0.67          | 0.67       | 0.67          |      |     |
| Associated acoustic parameters | $p_{r,a}$ at $z_{MI}$                      | (MPa)                 | 3.57       |               |            |               |      |     |
|                                | $P$  | (mW)                  |            | 15.27         | 15.27      |               | N/A  |     |
|                                | $P_{1X1}$                                  | (mW)                  |            | 15.27         | 15.27      |               |      |     |
|                                | $z_s$                                      | (cm)                  |            |               | -          |               |      |     |
|                                | $z_b$                                      | (cm)                  |            |               |            | -             |      |     |
|                                | $z_{MI}$                                   | (cm)                  | 0.42       |               |            |               |      |     |
|                                | $z_{PII,a}$                                | (cm)                  | 0.42       |               |            |               |      |     |
|                                | $f_{awf}$                                  | (MHz)                 | 10.08      | 9.16          | 9.16       | 9.16          | 9.16 | N/A |
| Other Information              | $p_{rr}$                                   | (Hz)                  | -          |               |            |               |      |     |
|                                | $S_{rr}$                                   | (Hz)                  | 99.00      |               |            |               |      |     |
|                                | $n_{pps}$                                  |                       | 1.00       |               |            |               |      |     |
|                                | $I_{pa,a}$ at $z_{PII,a}$                  | (W/cm <sup>2</sup> )  | 440.21     |               |            |               |      |     |
|                                | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 9.92       |               |            |               |      |     |
|                                | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 7.85       |               |            |               |      |     |
|                                | $pr$ at $z_{PII}$                          | (MPa)                 | 3.71       |               |            |               |      |     |
| Operating control conditions   | B Frequency                                |                       | Level 2    | Level 2       |            | Level 2       |      | N/A |
|                                | B Display Depth(mm)                        |                       | 15.00      | 50.00         |            | 50.00         |      | N/A |
|                                | B Focus Pos(mm)                            |                       | 10.00      | 45.00         |            | 45.00         |      | N/A |
|                                | B FOV                                      |                       | Med.       | Small         |            | Small         |      | N/A |
|                                | B Line Density                             |                       | Low        | Low           |            | Low           |      | N/A |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.

**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: L17-7Q

Operating Mode: B+M

| Index label                    |  | MI                    | TIS        |               | TIB        |               | TIC   |     |
|--------------------------------|--|-----------------------|------------|---------------|------------|---------------|-------|-----|
|                                |  |                       | At surface | Below surface | At surface | Below surface |       |     |
| Maximum index value            |  | 1.19                  | 0.55       |               | 0.55       |               | N/A   |     |
| Index Component Value          |  |                       | 0.55       | 0.54          | 0.55       | 0.54          |       |     |
| Associated acoustic parameters | $p_{r,\alpha}$ at $z_{MI}$                 | (MPa)                 | 3.12       |               |            |               |       |     |
|                                | $P$  | (mW)                  |            | 10.24         | 10.24      |               | N/A   |     |
|                                | $P_{1 \times 1}$                           | (mW)                  |            | 10.24         | 10.24      |               |       |     |
|                                | $z_s$                                      | (cm)                  |            |               | 0.30       |               |       |     |
|                                | $z_b$                                      | (cm)                  |            |               |            | 0.30          |       |     |
|                                | $z_{MI}$                                   | (cm)                  | 0.96       |               |            |               |       |     |
|                                | $z_{PII,a}$                                | (cm)                  | 0.96       |               |            |               |       |     |
|                                | $f_{awf}$                                  | (MHz)                 | 6.90       | 11.22         | 11.22      | 11.22         | 11.22 | N/A |
| Other Information              | $p_{rr}$                                   | (Hz)                  | 1000.00    |               |            |               |       |     |
|                                | $S_{rr}$                                   | (Hz)                  | -          |               |            |               |       |     |
|                                | $n_{pps}$                                  |                       | 1.00       |               |            |               |       |     |
|                                | $I_{pa,\alpha}$ at $z_{PII,a}$             | (W/cm <sup>2</sup> )  | 434.89     |               |            |               |       |     |
|                                | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 154.93     |               |            |               |       |     |
|                                | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 241.33     |               |            |               |       |     |
|                                | $pr$ at $z_{PII}$                          | (MPa)                 | 3.80       |               |            |               |       |     |
| Operating control conditions   | B Frequency                                | Level 1               | Level H1   |               | Level H1   |               | N/A   |     |
|                                | B Display Depth(mm)                        | 110.00                | 50.00      |               | 50.00      |               | N/A   |     |
|                                | B Focus Pos(mm)                            | 15.00                 | 50.00      |               | 50.00      |               | N/A   |     |
|                                | B FOV                                      | Small                 | Full       |               | Full       |               | N/A   |     |
|                                | B Line Density                             | Low                   | Low        |               | Low        |               | N/A   |     |
|                                | M Sweep Speed                              | Fast                  | Slow       |               | Slow       |               | N/A   |     |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.



**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: L17-7Q

Operating Mode: B+C/B+PDI/B+DPDI

| Index label                    |   | MI                    | TIS        |               | TIB        |               | TIC  |
|--------------------------------|---|-----------------------|------------|---------------|------------|---------------|------|
|                                |   |                       | At surface | Below surface | At surface | Below surface |      |
| Maximum index value            |   | 0.81                  | 0.69       |               | 0.69       |               | N/A  |
| Index Component Value          |   |                       | 0.69       | 0.69          | 0.69       | 0.69          |      |
| Associated acoustic parameters | $p_{r,\alpha}$ at $z_{MI}$                                      | (MPa)                 | 2.49       |               |            |               |      |
|                                | $P$   | (mW)                  |            | 17.98         | 17.98      |               | N/A  |
|                                | $P_{1X1}$   | (mW)                  |            | 17.98         | 17.98      |               |      |
|                                | $z_s$   | (cm)                  |            | -             |            |               |      |
|                                | $z_b$   | (cm)                  |            |               |            | -             |      |
|                                | $z_{MI}$  | (cm)                  | 1.12       |               |            |               |      |
|                                | $z_{P_{II},\alpha}$   | (cm)                  | 1.12       |               |            |               |      |
|                                | $f_{awf}$   | (MHz)                 | 9.41       | 8.07          | 8.07       | 8.07          | 8.07 |
| Other Information              | $p_{rr}$  | (Hz)                  | -          |               |            |               |      |
|                                | $S_{rr}$  | (Hz)                  | 28.60      |               |            |               |      |
|                                | $n_{pps}$   |                       | 1.00       |               |            |               |      |
|                                | $I_{pa,\alpha}$ at $z_{P_{II},\alpha}$                          | (W/cm <sup>2</sup> )  | 187.28     |               |            |               |      |
|                                | $I_{spta,\alpha}$ at $z_{P_{II},\alpha}$ or $z_{S_{II},\alpha}$ | (mW/cm <sup>2</sup> ) | 1.13       |               |            |               |      |
|                                | $I_{spta}$ at $z_{P_{II}}$ or $z_{S_{II}}$                      | (mW/cm <sup>2</sup> ) | 1.13       |               |            |               |      |
|                                | $p_r$ at $z_{P_{II}}$   | (MPa)                 | 3.70       |               |            |               |      |
| Operating control conditions   | B Frequency   | Level 2               | Level 2    |               | Level 2    |               | N/A  |
|                                | B Display Depth(mm)   | 30.00                 | 30.00      |               | 30.00      |               | N/A  |
|                                | B FOV   | Small                 | Small      |               | Small      |               | N/A  |
|                                | B Line Density  | High                  | High       |               | High       |               | N/A  |
|                                | C Frequency   | Level 0               | Level 0    |               | Level 0    |               | N/A  |
|                                | C Left Edge of ROI(mm)  | -4.75                 | -4.75      |               | -4.75      |               | N/A  |
|                                | C Right Edge of ROI(mm)   | 4.75                  | 4.75       |               | 4.75       |               | N/A  |
|                                | C Up Edge of ROI(mm)  | 13.00                 | 13.00      |               | 13.00      |               | N/A  |
|                                | C Down Edge of ROI(mm)  | 22.00                 | 22.00      |               | 22.00      |               | N/A  |
|                                | C Line Density  | Low                   | Low        |               | Low        |               | N/A  |
|                                | C PRF(KHz)  | 8.00                  | 8.00       |               | 8.00       |               | N/A  |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.

**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: L17-7Q

Operating Mode: PW/B+PW/B+C+PW

| Index label                    |  | MI                    | TIS        |               | TIB        |               | TIC  |     |
|--------------------------------|--|-----------------------|------------|---------------|------------|---------------|------|-----|
|                                |  |                       | At surface | Below surface | At surface | Below surface |      |     |
| Maximum index value            |  | 1.24                  | 0.35       |               | 0.90       |               | N/A  |     |
| Index Component Value          |  |                       | 0.35       | 0.29          | 0.35       | 0.90          |      |     |
| Associated acoustic parameters | $p_{r,a}$ at $z_{MI}$                      | (MPa)                 | 4.03       |               |            |               |      |     |
|                                | $P$  | (mW)                  |            | 9.06          |            | 9.06          |      | N/A |
|                                | $P_{1X1}$                                  | (mW)                  |            | 9.06          |            | 9.06          |      |     |
|                                | $z_s$                                      | (cm)                  |            |               | 0.30       |               |      |     |
|                                | $z_b$                                      | (cm)                  |            |               |            |               | 1.01 |     |
|                                | $z_{MI}$                                   | (cm)                  | 0.30       |               |            |               |      |     |
|                                | $z_{PII,a}$                                | (cm)                  | 0.30       |               |            |               |      |     |
|                                | $f_{awf}$                                  | (MHz)                 | 10.56      | 8.06          | 8.06       | 8.06          | 8.06 | N/A |
| Other Information              | $p_{rr}$                                   | (Hz)                  | -          |               |            |               |      |     |
|                                | $S_{rr}$                                   | (Hz)                  | 13.84      |               |            |               |      |     |
|                                | $n_{pps}$                                  |                       | 1.00       |               |            |               |      |     |
|                                | $I_{pa,a}$ at $z_{PII,a}$                  | (W/cm <sup>2</sup> )  | 708.57     |               |            |               |      |     |
|                                | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 1.64       |               |            |               |      |     |
|                                | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 1.51       |               |            |               |      |     |
|                                | $p_r$ at $z_{PII}$                         | (MPa)                 | 4.70       |               |            |               |      |     |
| Operating control conditions   | B Frequency                                | Level 2               | -          |               | -          |               | N/A  |     |
|                                | B Display Depth(mm)                        | 10.00                 | -          |               | -          |               | N/A  |     |
|                                | B Focus Pos(mm)                            | 5.00                  | -          |               | -          |               | N/A  |     |
|                                | B FOV                                      | Small                 | -          |               | -          |               | N/A  |     |
|                                | B Line Density                             | Low                   | -          |               | -          |               | N/A  |     |
|                                | PW Frequency                               | Level 1               | Level 1    |               | Level 1    |               | N/A  |     |
|                                | PW SV Depth(mm)                            | 5.00                  | 22.50      |               | 22.50      |               | N/A  |     |
|                                | PW PRF(KHz)                                | 14.70                 | 3.70       |               | 3.70       |               | N/A  |     |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.

## 1.4. Acoustic Output Table for P5-1Q

### Acoustic Output Reporting Table for IEC60601-2-37

Transducer Model: P5-1Q

Operating Mode: B

| Index label   |  | MI                    | TIS        |               | TIB        |               | TIC     |
|---|--|-----------------------|------------|---------------|------------|---------------|---------|
|   |  |                       | At surface | Below surface | At surface | Below surface |         |
| Maximum index value   |  | 1.35                  | 0.59       |               | 0.59       |               | 1.25    |
| Index Component Value   |  |                       | 0.59       | 0.59          | 0.59       | 0.59          |         |
| Associated acoustic parameters  | $p_{r,\alpha}$ at $z_{MI}$                 | (MPa)                 | 2.22       |               |            |               |         |
|   | $P$  | (mW)                  |            | 73.95         | 73.95      |               | 73.95   |
|   | $P_{1X1}$                                  | (mW)                  |            | 43.32         | 43.32      |               |         |
|   | $z_s$                                      | (cm)                  |            |               | -          |               |         |
|   | $z_b$                                      | (cm)                  |            |               |            | -             |         |
|   | $z_{MI}$                                   | (cm)                  | 4.77       |               |            |               |         |
|   | $z_{PII,a}$                                | (cm)                  | 4.77       |               |            |               |         |
|   | $f_{awf}$                                  | (MHz)                 | 2.70       | 2.84          | 2.84       | 2.84          | 2.84    |
| Other Information   | $p_{rr}$                                   | (Hz)                  | -          |               |            |               |         |
|   | $S_{rr}$                                   | (Hz)                  | 62.00      |               |            |               |         |
|   | $n_{pps}$                                  |                       | 1.00       |               |            |               |         |
|   | $I_{pa,\alpha}$ at $z_{PII,a}$             | (W/cm <sup>2</sup> )  | 206.10     |               |            |               |         |
|   | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 18.66      |               |            |               |         |
|   | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 18.21      |               |            |               |         |
|   | $pr$ at $z_{PII}$                          | (MPa)                 | 3.49       |               |            |               |         |
| Operating control conditions  | B Frequency                                |                       | Level 2    | Level 2       | Level 2    | Level 2       | Level 2 |
|   | B Display Depth(mm)                        |                       | 300.00     | 300.00        | 300.00     | 300.00        | 300.00  |
|   | B Focus Pos(mm)                            |                       | 80.00      | 200.00        | 200.00     | 200.00        | 200.00  |
|   | B FOV                                      |                       | Small      | Med.          | Med.       | Med.          | Med.    |
|   | B Line Density                             |                       | Low        | Low           | Low        | Low           | Low     |
| Note:   |  |                       |            |               |            |               |         |
| 1. (-) This index or parameter is not required for this operating mode. |  |                       |            |               |            |               |         |

## Acoustic Output Reporting Table for IEC60601-2-37

Transducer Model: P5-1Q

Operating Mode: B+M

| Index label                    |  | MI                    | TIS        |               | TIB        |               | TIC   |          |
|--------------------------------|--|-----------------------|------------|---------------|------------|---------------|-------|----------|
|                                |  |                       | At surface | Below surface | At surface | Below surface |       |          |
| Maximum index value            |  | 1.24                  | 0.69       |               | 1.57       |               | 1.54  |          |
| Index Component Value          |  |                       | 0.60       | 0.69          | 0.55       | 1.57          |       |          |
| Associated acoustic parameters | $p_{r,\alpha}$ at $z_{MI}$                 | (MPa)                 | 1.77       |               |            |               |       |          |
|                                | $P$  | (mW)                  |            | 74.45         | 85.90      |               | 85.90 |          |
|                                | $P_{1 \times 1}$                           | (mW)                  |            | 43.62         | 56.36      |               |       |          |
|                                | $z_s$                                      | (cm)                  |            |               | 0.75       |               |       |          |
|                                | $z_b$                                      | (cm)                  |            |               |            | 3.32          |       |          |
|                                | $z_{MI}$                                   | (cm)                  | 3.57       |               |            |               |       |          |
|                                | $z_{PII,a}$                                | (cm)                  | 3.57       |               |            |               |       |          |
|                                | $f_{awf}$                                  | (MHz)                 | 2.04       | 2.89          | 2.89       | 2.04          | 2.04  |          |
| Other Information              | $p_{rr}$                                   | (Hz)                  | 1000.00    |               |            |               |       |          |
|                                | $S_{rr}$                                   | (Hz)                  | -          |               |            |               |       |          |
|                                | $n_{pps}$                                  |                       | 1.00       |               |            |               |       |          |
|                                | $I_{pa,\alpha}$ at $z_{PII,a}$             | (W/cm <sup>2</sup> )  | 130.17     |               |            |               |       |          |
|                                | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 101.55     |               |            |               |       |          |
|                                | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 170.09     |               |            |               |       |          |
|                                | $pr$ at $z_{PII}$                          | (MPa)                 | 2.26       |               |            |               |       |          |
| Operating control conditions   | B Frequency                                |                       | Level H1   | Level 1       |            | Level H1      |       | Level H1 |
|                                | B Display Depth(mm)                        |                       | 40.00      | 200.00        |            | 40.00         |       | 40.00    |
|                                | B Focus Pos(mm)                            |                       | 40.00      | 200.00        |            | 40.00         |       | 40.00    |
|                                | B FOV                                      |                       | Small      | Full          |            | Small         |       | Small    |
|                                | B Line Density                             |                       | Low        | Low           |            | Low           |       | Low      |
|                                | M Sweep Speed                              |                       | Fast       | Fast          |            | Fast          |       | Fast     |

Note:

1. (-) This index or parameter is not required for this operating mode.

**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: P5-1Q

Operating Mode: B+C/B+PDI/B+DPDI

| Index label                    |   | MI                    | TIS        |               | TIB        |               | TIC     |
|--------------------------------|---|-----------------------|------------|---------------|------------|---------------|---------|
|                                |   |                       | At surface | Below surface | At surface | Below surface |         |
| Maximum index value            |   | 1.19                  | 0.65       |               | 0.65       |               | 2.67    |
| Index Component Value          |   |                       | 0.65       | 0.65          | 0.65       | 0.65          |         |
| Associated acoustic parameters | $p_{r,\alpha}$ at $z_{MI}$                                      | (MPa)                 | 2.10       |               |            |               |         |
|                                | $P$   | (mW)                  |            | 73.69         | 73.69      |               | 86.94   |
|                                | $P_{1X1}$   | (mW)                  |            | 59.89         | 59.89      |               |         |
|                                | $z_s$   | (cm)                  |            |               | -          |               |         |
|                                | $z_b$   | (cm)                  |            |               |            | -             |         |
|                                | $z_{MI}$  | (cm)                  | 4.32       |               |            |               |         |
|                                | $z_{P_{II},\alpha}$   | (cm)                  | 4.32       |               |            |               |         |
|                                | $f_{awf}$   | (MHz)                 | 3.11       | 2.21          | 2.21       | 2.21          | 2.21    |
| Other Information              | $p_{rr}$  | (Hz)                  | -          |               |            |               |         |
|                                | $S_{rr}$  | (Hz)                  | 26.72      |               |            |               |         |
|                                | $\eta_{pps}$  |                       | 1.00       |               |            |               |         |
|                                | $I_{pa,\alpha}$ at $z_{P_{II},\alpha}$                          | (W/cm <sup>2</sup> )  | 179.54     |               |            |               |         |
|                                | $I_{spta,\alpha}$ at $z_{P_{II},\alpha}$ or $z_{S_{II},\alpha}$ | (mW/cm <sup>2</sup> ) | 2.64       |               |            |               |         |
|                                | $I_{spta}$ at $z_{P_{II}}$ or $z_{S_{II}}$                      | (mW/cm <sup>2</sup> ) | 2.48       |               |            |               |         |
|                                | $pr$ at $z_{P_{II}}$  | (MPa)                 | 3.24       |               |            |               |         |
| Operating control conditions   | B Frequency   |                       | Level 2    | Level 2       | Level 2    | Level 2       | Level 2 |
|                                | B Display Depth(mm)   |                       | 240.00     | 240.00        | 240.00     | 240.00        | 240     |
|                                | B FOV   |                       | Small      | Small         | Small      | Small         | Small   |
|                                | B Line Density  |                       | High       | High          | High       | High          | High    |
|                                | C Frequency   |                       | Level 0    | Level 1       | Level 1    | Level 1       | Level 1 |
|                                | C Left Edge of ROI(mm)  |                       | -12.50     | -12.50        | -12.50     | -12.50        | -12.5   |
|                                | C Right Edge of ROI(mm)   |                       | 12.50      | 12.50         | 12.50      | 12.50         | 12.5    |
|                                | C Up Edge of ROI(mm)  |                       | 63.50      | 193.50        | 193.50     | 193.50        | 193.5   |
|                                | C Down Edge of ROI(mm)  |                       | 72.50      | 202.50        | 202.50     | 202.50        | 202.5   |
|                                | C Line Density  |                       | Low        | Low           | Low        | Low           | Low     |
|                                | C PRF(KHz)  |                       | 4.60       | 1.90          | 1.90       | 1.90          | 1.9     |

Note:

1. (-) This index or parameter is not required for this operating mode.

**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: P5-1Q

Operating Mode: PW/B+PW/B+C+PW

| Index label                    |  | MI                    | TIS        |               | TIB        |               | TIC    |
|--------------------------------|--|-----------------------|------------|---------------|------------|---------------|--------|
|                                |  |                       | At surface | Below surface | At surface | Below surface |        |
| Maximum index value            |  | 1.40                  | 1.12       |               | 3.55       |               | 2.54   |
| Index Component Value          |  |                       | 0.98       | 1.12          | 0.82       | 3.55          |        |
| Associated acoustic parameters | $p_{r,\alpha}$ at $z_{MI}$                 | (MPa)                 | 1.98       |               |            |               |        |
|                                | $P$  | (mW)                  |            | 111.83        | 103.57     |               | 113.52 |
|                                | $P_{1X1}$                                  | (mW)                  |            | 93.19         |            | 86.31         |        |
|                                | $z_s$                                      | (cm)                  |            |               | 0.35       |               |        |
|                                | $z_b$                                      | (cm)                  |            |               |            | 3.22          |        |
|                                | $Z_{MI}$                                   | (cm)                  | 1.15       |               |            |               |        |
|                                | $Z_{PII,a}$                                | (cm)                  | 1.15       |               |            |               |        |
|                                | $f_{awf}$                                  | (MHz)                 | 2.00       | 2.21          | 2.21       | 2.00          | 2.00   |
| Other Information              | $p_{rr}$                                   | (Hz)                  | 900.00     |               |            |               |        |
|                                | $S_{rr}$                                   | (Hz)                  | -          |               |            |               |        |
|                                | $n_{pps}$                                  |                       | 1.00       |               |            |               |        |
|                                | $I_{pa,\alpha}$ at $Z_{PII,a}$             | (W/cm <sup>2</sup> )  | 141.60     |               |            |               |        |
|                                | $I_{spta,a}$ at $Z_{PII,a}$ or $Z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 283.33     |               |            |               |        |
|                                | $I_{spta}$ at $Z_{PII}$ or $Z_{SII}$       | (mW/cm <sup>2</sup> ) | 286.23     |               |            |               |        |
|                                | $p_r$ at $Z_{PII}$                         | (MPa)                 | 1.71       |               |            |               |        |
| Operating control conditions   | B Frequency                                | -                     | -          | -             | -          | -             |        |
|                                | B Display Depth(mm)                        | -                     | -          | -             | -          | -             |        |
|                                | B Focus Pos(mm)                            | -                     | -          | -             | -          | -             |        |
|                                | B FOV                                      | -                     | -          | -             | -          | -             |        |
|                                | B Line Density                             | -                     | -          | -             | -          | -             |        |
|                                | PW Frequency                               | Level 0               | Level 1    | Level 0       | Level 0    |               |        |
|                                | PW SV Depth(mm)                            | 30.00                 | 150.00     | 60.00         | 60.00      |               |        |
|                                | PW PRF(KHz)                                | 0.90                  | 3.70       | 1.50          | 1.50       |               |        |

Note:

1. (-) This index or parameter is not required for this operating mode.

**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: P5-1Q

Operating Mode: CW

| Index label   |  | MI                    | TIS        |               | TIB        |               | TIC     |  |
|---|--|-----------------------|------------|---------------|------------|---------------|---------|--|
|   |  |                       | At surface | Below surface | At surface | Below surface |         |  |
| Maximum index value   |  | 0.08                  | 0.89       |               | 3.34       |               | 2.19    |  |
| Index Component Value   |  |                       | 0.78       | 0.89          | 0.78       | 3.34          |         |  |
| Associated acoustic parameters  | $p_{r,\alpha}$ at $z_{MI}$                 | (MPa)                 | 0.11       |               |            |               |         |  |
|   | $P$  | (mW)                  |            | 97.89         | 97.89      |               | 97.89   |  |
|   | $P_{1X1}$                                  | (mW)                  |            | 81.57         |            | 81.57         |         |  |
|   | $z_s$                                      | (cm)                  |            |               | 0.37       |               |         |  |
|   | $z_b$                                      | (cm)                  |            |               |            | 2.81          |         |  |
|   | $z_{MI}$                                   | (cm)                  | 3.36       |               |            |               |         |  |
|   | $z_{PII,a}$                                | (cm)                  | 3.36       |               |            |               |         |  |
|   | $f_{awf}$                                  | (MHz)                 | 2.00       | 2.00          | 2.00       | 2.00          | 2.00    |  |
| Other Information   | $p_{rr}$                                   | (Hz)                  | 200000.00  |               |            |               |         |  |
|   | $S_{rr}$                                   | (Hz)                  | -          |               |            |               |         |  |
|   | $n_{pps}$                                  |                       | 1.00       |               |            |               |         |  |
|   | $I_{pa,\alpha}$ at $z_{PII,a}$             | (W/cm <sup>2</sup> )  | 0.44       |               |            |               |         |  |
|   | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 439.55     |               |            |               |         |  |
|   | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 699.45     |               |            |               |         |  |
|   | $p_r$ at $z_{PII}$                         | (MPa)                 | 0.14       |               |            |               |         |  |
| Operating control conditions  | CW Frequency                               |                       | Level 0    | Level 0       |            | Level 0       | Level 0 |  |
|   | CW Focus Depth(mm)                         |                       | 40.00      | 40.00         |            | 40.00         | 40.00   |  |
|   | B Display Depth(mm)                        |                       | 180.00     | 180.00        |            | 180.00        | 180.00  |  |
|   | B FOV                                      |                       | Full       | Full          |            | Full          | Full    |  |
| Note:   |  |                       |            |               |            |               |         |  |
| 1. (-) This index or parameter is not required for this operating mode. |  |                       |            |               |            |               |         |  |

## 1.5. Acoustic Output Table for E8-4Q

### Acoustic Output Reporting Table for IEC60601-2-37

Transducer Model: E8-4Q

Operating Mode: B

| Index label   |  | MI                    | TIS        |               | TIB        |               | TIC |
|---|--|-----------------------|------------|---------------|------------|---------------|-----|
|   |  |                       | At surface | Below surface | At surface | Below surface |     |
| Maximum index value   |  | 1.40                  | 0.45       |               | 0.45       |               | N/A |
| Index Component Value   |  |                       | 0.45       | 0.45          | 0.45       | 0.45          |     |
| Associated acoustic parameters  | $p_{r,\alpha}$ at $z_{MI}$                 | (MPa)                 | 3.05       |               |            |               |     |
|   | P  | (mW)                  |            | 19.91         | 19.91      |               | N/A |
|   | $P_{1 \times 1}$                           | (mW)                  |            | 19.91         | 19.91      |               |     |
|   | $z_s$                                      | (cm)                  |            |               | -          |               |     |
|   | $z_b$                                      | (cm)                  |            |               |            | -             |     |
|   | $z_{MI}$                                   | (cm)                  | 1.26       |               |            |               |     |
|   | $z_{PII,a}$                                | (cm)                  | 1.26       |               |            |               |     |
|   | f <sub>awf</sub>                           | (MHz)                 | 4.71       | 4.71          | 4.71       | 4.71          | N/A |
| Other Information   | p <sub>rr</sub>                            | (Hz)                  | -          |               |            |               |     |
|   | S <sub>rr</sub>                            | (Hz)                  | 57.00      |               |            |               |     |
|   | $\eta_{pps}$                               |                       | 1.00       |               |            |               |     |
|   | $I_{pa,\alpha}$ at $z_{PII,a}$             | (W/cm <sup>2</sup> )  | 455.62     |               |            |               |     |
|   | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 15.43      |               |            |               |     |
|   | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 14.10      |               |            |               |     |
|   | p <sub>r</sub> at $z_{PII}$                | (MPa)                 | 3.53       |               |            |               |     |
| Operating control conditions  | B Frequency                                | Level 1               | Level 1    |               | Level 1    |               | N/A |
|   | B Display Depth(mm)                        | 110.00                | 110.00     |               | 110.00     |               | N/A |
|   | B Focus Pos(mm)                            | 40.00                 | 40.00      |               | 40.00      |               | N/A |
|   | B FOV                                      | Full                  | Full       |               | Full       |               | N/A |
|   | B Line Density                             | Low                   | Low        |               | Low        |               | N/A |
| Note:   |  |                       |            |               |            |               |     |
| 1. (-) This index or parameter is not required for this operating mode. |  |                       |            |               |            |               |     |
| 2. (N/A) This transducer is not intended for cephalic examination.      |  |                       |            |               |            |               |     |



**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: E8-4Q

Operating Mode: B+M

| Index label                    |  | MI                    | TIS        |               | TIB        |               | TIC  |
|--------------------------------|--|-----------------------|------------|---------------|------------|---------------|------|
|                                |  |                       | At surface | Below surface | At surface | Below surface |      |
| Maximum index value            |  | 1.47                  | 0.34       |               | 0.43       |               | N/A  |
| Index Component Value          |  |                       | 0.34       | 0.34          | 0.34       | 0.43          |      |
| Associated acoustic parameters | $p_{r,\alpha}$ at $z_{MI}$                 | (MPa)                 | 3.20       |               |            |               |      |
|                                | P  | (mW)                  |            | 18.32         | 18.32      |               | N/A  |
|                                | $P_{1 \times 1}$                           | (mW)                  |            | 18.32         | 18.32      |               |      |
|                                | $z_s$                                      | (cm)                  |            |               | 0.30       |               |      |
|                                | $z_b$                                      | (cm)                  |            |               |            | 1.36          |      |
|                                | $z_{MI}$                                   | (cm)                  | 1.26       |               |            |               |      |
|                                | $z_{PII,a}$                                | (cm)                  | 1.26       |               |            |               |      |
|                                | $f_{awf}$                                  | (MHz)                 | 4.74       | 3.93          | 3.93       | 3.93          | 3.92 |
| Other Information              | pr   | (Hz)                  | 83.33      |               |            |               |      |
|                                | Srr  | (Hz)                  | -          |               |            |               |      |
|                                | npps                                       |                       | 1.00       |               |            |               |      |
|                                | $I_{pa,\alpha}$ at $z_{PII,a}$             | (W/cm <sup>2</sup> )  | 547.76     |               |            |               |      |
|                                | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 14.34      |               |            |               |      |
|                                | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 21.19      |               |            |               |      |
| pr at $z_{PII}$                | (MPa)                                      | 3.73                  |            |               |            |               |      |
| Operating control conditions   | B Frequency                                | Level 1               | Level H0   |               | Level H0   |               | N/A  |
|                                | B Display Depth(mm)                        | 110.00                | 60.00      |               | 60.00      |               | N/A  |
|                                | B Focus Pos(mm)                            | 30.00                 | 60.00      |               | 60.00      |               | N/A  |
|                                | B FOV                                      | Small                 | Full       |               | Full       |               | N/A  |
|                                | B Line Density                             | Low                   | Low        |               | Low        |               | N/A  |
|                                | M Sweep Speed                              | Slow                  | Low        |               | Low        |               | N/A  |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.

**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: E8-4Q

Operating Mode: B+C/B+PDI/B+DPDI

| Index label                    |                                  | MI                    | TIS        |               | TIB        |               | TIC  |     |
|--------------------------------|----------------------------------|-----------------------|------------|---------------|------------|---------------|------|-----|
|                                |                                  |                       | At surface | Below surface | At surface | Below surface |      |     |
| Maximum index value            |                                  | 1.08                  | 0.30       |               | 0.30       |               | N/A  |     |
| Index Component Value          |                                  |                       | 0.30       | 0.30          | 0.30       | 0.30          |      |     |
| Associated acoustic parameters | $p_{r,\alpha}$ at zMI            | (MPa)                 | 2.61       |               |            |               |      |     |
|                                | P                                | (mW)                  |            | 15.28         | 15.28      |               | N/A  |     |
|                                | $P_{1X1}$                        | (mW)                  |            | 15.28         | 15.28      |               |      |     |
|                                | Zs                               | (cm)                  |            |               | -          |               |      |     |
|                                | Zb                               | (cm)                  |            |               |            | -             |      |     |
|                                | ZMI                              | (cm)                  | 0.96       |               |            |               |      |     |
|                                | ZPII,a                           | (cm)                  | 0.96       |               |            |               |      |     |
|                                | fawf                             | (MHz)                 | 5.82       | 3.65          | 3.65       | 3.65          | 3.65 | N/A |
| Other Information              | pr                               | (Hz)                  | -          |               |            |               |      |     |
|                                | Srr                              | (Hz)                  | 27.40      |               |            |               |      |     |
|                                | npps                             |                       | 1.00       |               |            |               |      |     |
|                                | $I_{pa,\alpha}$ at ZPII,a        | (W/cm <sup>2</sup> )  | 286.28     |               |            |               |      |     |
|                                | $I_{spta,a}$ at ZPII,a or ZSII,a | (mW/cm <sup>2</sup> ) | 3.59       |               |            |               |      |     |
|                                | $I_{spta}$ at ZPII or ZSII       | (mW/cm <sup>2</sup> ) | 3.54       |               |            |               |      |     |
|                                | pr at ZPII                       | (MPa)                 | 3.04       |               |            |               |      |     |
| Operating control conditions   | B Frequency                      |                       | Level 2    | Level 2       |            | Level 2       |      | N/A |
|                                | B Display Depth(mm)              |                       | 115.00     | 115.00        |            | 115.00        |      | N/A |
|                                | B FOV                            |                       | Small      | Small         |            | Small         |      | N/A |
|                                | B Line Density                   |                       | High       | High          |            | High          |      | N/A |
|                                | C Frequency                      |                       | Level 0    | Level 0       |            | Level 0       |      | N/A |
|                                | C Left Edge of ROI(mm)           |                       | -18.50     | -18.50        |            | -18.50        |      | N/A |
|                                | C Right Edge of ROI(mm)          |                       | 18.50      | 18.50         |            | 18.50         |      | N/A |
|                                | C Up Edge of ROI(mm)             |                       | 20.50      | 5.50          |            | 5.50          |      | N/A |
|                                | C Down Edge of ROI(mm)           |                       | 29.50      | 14.50         |            | 14.50         |      | N/A |
|                                | C Line Density                   |                       | Low        | Low           |            | Low           |      | N/A |
|                                | C PRF(KHz)                       |                       | 8.00       | 0.60          |            | 0.60          |      | N/A |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.

**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: E8-4Q

Operating Mode: PW/B+PW/B+C+PW

| Index label                    |  | MI                    | TIS        |               | TIB        |               | TIC  |
|--------------------------------|--|-----------------------|------------|---------------|------------|---------------|------|
|                                |  |                       | At surface | Below surface | At surface | Below surface |      |
| Maximum index value            |  | 1.46                  | 0.24       |               | 0.96       |               | N/A  |
| Index Component Value          |  |                       | 0.24       | 0.22          | 0.23       | 0.96          |      |
| Associated acoustic parameters | $p_{r,\alpha}$ at $z_{MI}$                 | (MPa)                 | 3.19       |               |            |               |      |
|                                | $P$  | (mW)                  |            | 10.21         | 13.00      |               | N/A  |
|                                | $P_{1X1}$                                  | (mW)                  |            | 10.21         | 13.00      |               |      |
|                                | $z_s$                                      | (cm)                  |            |               | 0.30       |               |      |
|                                | $z_b$                                      | (cm)                  |            |               |            | 0.70          |      |
|                                | $z_{MI}$                                   | (cm)                  | 0.81       |               |            |               |      |
|                                | $z_{PII,a}$                                | (cm)                  | 0.81       |               |            |               |      |
|                                | $f_{awf}$                                  | (MHz)                 | 4.79       | 4.99          | 4.99       | 3.66          | 3.66 |
| Other Information              | $p_{rr}$                                   | (Hz)                  | -          |               |            |               |      |
|                                | $S_{rr}$                                   | (Hz)                  | 612.50     |               |            |               |      |
|                                | $\eta_{pps}$                               |                       | 1.00       |               |            |               |      |
|                                | $I_{pa,\alpha}$ at $z_{PII,a}$             | (W/cm <sup>2</sup> )  | 502.92     |               |            |               |      |
|                                | $I_{spta,a}$ at $z_{PII,a}$ or $z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 4.63       |               |            |               |      |
|                                | $I_{spta}$ at $z_{PII}$ or $z_{SII}$       | (mW/cm <sup>2</sup> ) | 4.26       |               |            |               |      |
|                                | $pr$ at $z_{PII}$                          | (MPa)                 | 3.55       |               |            |               |      |
| Operating control conditions   | B Frequency                                | Level 0               | -          | -             | -          | -             | N/A  |
|                                | B Display Depth(mm)                        | 30.00                 | -          | -             | -          | -             | N/A  |
|                                | B Focus Pos(mm)                            | 22.50                 | -          | -             | -          | -             | N/A  |
|                                | B FOV                                      | Small                 | -          | -             | -          | -             | N/A  |
|                                | B Line Density                             | Low                   | -          | -             | -          | -             | N/A  |
|                                | PW Frequency                               | Level 0               | Level 1    | Level 0       | Level 0    | Level 0       | N/A  |
|                                | PW SV Depth(mm)                            | 22.50                 | 70.00      | 60.00         | 60.00      | 60.00         | N/A  |
|                                | PW PRF(KHz)                                | 0.90                  | 3.70       | 0.90          | 0.90       | 0.90          | N/A  |

Note:

1. (-) This index or parameter is not required for this operating mode.
2. (N/A) This transducer is not intended for cephalic examination.

## 1.6. Acoustic Output Table for L17-7HQ

### Acoustic Output Reporting Table for IEC60601-2-37

Transducer Model: L17-7HQ

Operating Mode: B

| Index label                    |  | MI                    | TIS        |               | TIB        |               | TIC   |     |
|--------------------------------|--|-----------------------|------------|---------------|------------|---------------|-------|-----|
|                                |  |                       | At surface | Below surface | At surface | Below surface |       |     |
| Maximum index value            |  | 1.06                  | 1.35       |               | 1.35       |               | N/A   |     |
| Index Component Value          |  |                       | 1.35       | 1.35          | 1.35       | 1.35          |       |     |
| Associated acoustic parameters | $p_{r,\alpha}$ at $z_{MI}$                 | (MPa)                 | 3.49       |               |            |               |       |     |
|                                | P  | (mW)                  |            | 27.33         | 27.33      |               | N/A   |     |
|                                | $P_{1X1}$                                  | (mW)                  |            | 27.33         | 27.33      |               |       |     |
|                                | $Z_s$                                      | (cm)                  |            |               | -          |               |       |     |
|                                | $Z_b$                                      | (cm)                  |            |               |            | -             |       |     |
|                                | $Z_{MI}$                                   | (cm)                  | 0.30       |               |            |               |       |     |
|                                | $Z_{PII,a}$                                | (cm)                  | 0.30       |               |            |               |       |     |
|                                | $f_{awf}$                                  | (MHz)                 | 10.80      | 10.40         | 10.40      | 10.40         | 10.40 | N/A |
| Other Information              | $p_{rr}$                                   | (Hz)                  | -          |               |            |               |       |     |
|                                | $S_{rr}$                                   | (Hz)                  | 72.00      |               |            |               |       |     |
|                                | $\eta_{pps}$                               |                       | 1.00       |               |            |               |       |     |
|                                | $I_{pa,\alpha}$ at $Z_{PII,a}$             | (W/cm <sup>2</sup> )  | 553.96     |               |            |               |       |     |
|                                | $I_{spta,a}$ at $Z_{PII,a}$ OR $Z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 6.89       |               |            |               |       |     |
|                                | $I_{spta}$ at $Z_{PII}$ OR $Z_{SII}$       | (mW/cm <sup>2</sup> ) | 6.64       |               |            |               |       |     |
|                                | $p_r$ at $Z_{PII}$                         | (MPa)                 | 3.58       |               |            |               |       |     |
| Operating control conditions   | B Frequency                                |                       | Level 2    | Level 2       | Level 2    |               | N/A   |     |
|                                | B Display Depth(mm)                        |                       | 110.00     | 50.00         | 50.00      |               | N/A   |     |
|                                | B Focus Pos(mm)                            |                       | 5.00       | 45.00         | 45.00      |               | N/A   |     |
|                                | B FOV                                      |                       | Small      | Full          | Full       |               | N/A   |     |
|                                | B Line Density                             |                       | Low        | Low           | Low        |               | N/A   |     |

Note:

- (-) This index or parameter is not required for this operating mode.
- (N/A) This transducer is not intended for cephalic examination.

## Acoustic Output Reporting Table for IEC60601-2-37

Transducer Model: L17-7HQ

Operating Mode: B+M

| Index label                    |  | MI                    | TIS        |               | TIB        |               | TIC  |
|--------------------------------|--|-----------------------|------------|---------------|------------|---------------|------|
|                                |  |                       | At surface | Below surface | At surface | Below surface |      |
| Maximum index value            |  | 1.05                  | 0.47       |               | 0.51       |               | N/A  |
| Index Component Value          |  |                       | 0.47       | 0.46          | 0.47       | 0.51          |      |
| Associated acoustic parameters | $p_{r,\alpha}$ at zMI                      | (MPa)                 | 3.44       |               |            |               |      |
|                                | P  | (mW)                  |            | 13.93         | 13.93      |               | N/A  |
|                                | $P_{1 \times 1}$                           | (mW)                  |            | 13.93         | 13.93      |               |      |
|                                | $Z_s$                                      | (cm)                  |            |               | 0.30       |               |      |
|                                | $Z_b$                                      | (cm)                  |            |               |            | 1.13          |      |
|                                | $Z_{MI}$                                   | (cm)                  | 0.30       |               |            |               |      |
|                                | $Z_{PII,a}$                                | (cm)                  | 0.30       |               |            |               |      |
|                                | $f_{awf}$                                  | (MHz)                 | 10.79      | 7.12          | 7.12       | 7.12          | 7.07 |
| Other Information              | pr   | (Hz)                  | 1000.00    |               |            |               |      |
|                                | Srr  | (Hz)                  | -          |               |            |               |      |
|                                | $\eta_{pps}$                               |                       | 1.00       |               |            |               |      |
|                                | $I_{pa,\alpha}$ at $Z_{PII,a}$             | (W/cm <sup>2</sup> )  | 529.35     |               |            |               |      |
|                                | $I_{spta,a}$ at $Z_{PII,a}$ or $Z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 121.91     |               |            |               |      |
|                                | $I_{spta}$ at $Z_{PII}$ or $Z_{SII}$       | (mW/cm <sup>2</sup> ) | 126.77     |               |            |               |      |
|                                | pr at $Z_{PII}$                            | (MPa)                 | 3.74       |               |            |               |      |
| Operating control conditions   | B Frequency                                | Level 2               | Level H0   |               | Level H0   |               | N/A  |
|                                | B Display Depth(mm)                        | 110.00                | 45.00      |               | 45.00      |               | N/A  |
|                                | B Focus Pos(mm)                            | 5.00                  | 45.00      |               | 45.00      |               | N/A  |
|                                | B FOV                                      | Small                 | Full       |               | Full       |               | N/A  |
|                                | B Line Density                             | Low                   | Low        |               | Low        |               | N/A  |
|                                | M Sweep Speed                              | Slow                  | High       |               | High       |               | N/A  |

## Note:

- (-) This index or parameter is not required for this operating mode.
- (N/A) This transducer is not intended for cephalic examination.

## Acoustic Output Reporting Table for IEC60601-2-37

Transducer Model: L17-7HQ

Operating Mode: B+C/B+PDI/B+DPDI

| Index label                    |                                  |                       | MI       | TIS        |               | TIB        |               | TIC |
|--------------------------------|----------------------------------|-----------------------|----------|------------|---------------|------------|---------------|-----|
|                                |                                  |                       |          | At surface | Below surface | At surface | Below surface |     |
| Maximum index value            |                                  |                       | 0.95     | 0.69       |               | 0.69       |               | N/A |
| Index Component Value          |                                  |                       |          | 0.69       | 0.69          | 0.69       | 0.69          |     |
| Associated acoustic parameters | $p_{r,\alpha}$ at zMI            | (MPa)                 | 3.08     |            |               |            |               |     |
|                                | P                                | (mW)                  |          | 17.33      |               | 17.33      |               | N/A |
|                                | $P_{1 \times 1}$                 | (mW)                  |          | 17.33      |               | 17.33      |               |     |
|                                | Zs                               | (cm)                  |          |            | -             |            |               |     |
|                                | Zb                               | (cm)                  |          |            |               |            | -             |     |
|                                | ZMI                              | (cm)                  | 0.30     |            |               |            |               |     |
|                                | ZPII,a                           | (cm)                  | 0.30     |            |               |            |               |     |
|                                | fawf                             | (MHz)                 | 10.44    | 8.05       | 8.05          | 8.05       | 8.05          | N/A |
| Other Information              | pr                               | (Hz)                  | -        |            |               |            |               |     |
|                                | Srr                              | (Hz)                  | 29.05    |            |               |            |               |     |
|                                | npps                             |                       | 1.00     |            |               |            |               |     |
|                                | $I_{pa,\alpha}$ at ZPII,a        | (W/cm <sup>2</sup> )  | 321.12   |            |               |            |               |     |
|                                | $I_{spta,a}$ at ZPII,a or ZSII,a | (mW/cm <sup>2</sup> ) | 1.59     |            |               |            |               |     |
|                                | $I_{spta}$ at ZPII or ZSII       | (mW/cm <sup>2</sup> ) | 1.31     |            |               |            |               |     |
|                                | pr at ZPII                       | (MPa)                 | 3.26     |            |               |            |               |     |
| Operating control conditions   | B Frequency                      |                       | Level H0 | Level 2    |               | Level 2    |               | N/A |
|                                | B Display Depth(mm)              |                       | 110.00   | 110.00     |               | 110.00     |               | N/A |
|                                | B FOV                            |                       | Small    | Small      |               | Small      |               | N/A |
|                                | B Line Density                   |                       | High     | High       |               | High       |               | N/A |
|                                | C Frequency                      |                       | Level 0  | Level 1    |               | Level 1    |               | N/A |
|                                | C Left Edge of ROI(mm)           |                       | 0.50     | 45.50      |               | 45.50      |               | N/A |
|                                | C Right Edge of ROI(mm)          |                       | 9.50     | 54.50      |               | 54.50      |               | N/A |
|                                | C Up Edge of ROI(mm)             |                       | 4.75     | 4.75       |               | 4.75       |               | N/A |
|                                | C Down Edge of ROI(mm)           |                       | 2.00     | 2.00       |               | 2.00       |               | N/A |
|                                | C Line Density                   |                       | Low      | Low        |               | Low        |               | N/A |
|                                | C PRF(KHz)                       |                       | 10.20    | 4.60       |               | 4.60       |               | N/A |

Note:

- (-) This index or parameter is not required for this operating mode.
- (N/A) This transducer is not intended for cephalic examination.

**Acoustic Output Reporting Table for IEC60601-2-37**

Transducer Model: L17-7HQ

Operating Mode: PW/B+PW/B+C+PW

| Index label   |  | MI                    | TIS        |               | TIB        |               | TIC  |     |
|---|--|-----------------------|------------|---------------|------------|---------------|------|-----|
|   |  |                       | At surface | Below surface | At surface | Below surface |      |     |
| Maximum index value   |  | 1.07                  | 0.21       |               | 0.55       |               | N/A  |     |
| Index Component Value   |  |                       | 0.21       | 0.20          | 0.15       | 0.55          |      |     |
| Associated acoustic parameters  | $p_{r,\alpha}$ at zMI                      | (MPa)                 | 3.50       |               |            |               |      |     |
|   | P  | (mW)                  |            | 5.91          | 4.54       |               | N/A  |     |
|   | $P_{1 \times 1}$                           | (mW)                  |            | 5.46          |            | 4.54          |      |     |
|   | $Z_s$                                      | (cm)                  |            |               | 0.30       |               |      |     |
|   | $Z_b$                                      | (cm)                  |            |               |            | 0.80          |      |     |
|   | $Z_{MI}$                                   | (cm)                  | 0.30       |               |            |               |      |     |
|   | $Z_{PII,a}$                                | (cm)                  | 0.30       |               |            |               |      |     |
|   | $f_{awf}$                                  | (MHz)                 | 10.77      | 6.72          | 6.72       | 6.75          | 6.75 | N/A |
| Other Information   | pr   | (Hz)                  | -          |               |            |               |      |     |
|   | Srr  | (Hz)                  | 12.50      |               |            |               |      |     |
|   | $\eta_{pps}$                               |                       | 1.00       |               |            |               |      |     |
|   | $I_{pa,\alpha}$ at $Z_{PII,a}$             | (W/cm <sup>2</sup> )  | 557.30     |               |            |               |      |     |
|   | $I_{spta,a}$ at $Z_{PII,a}$ or $Z_{SII,a}$ | (mW/cm <sup>2</sup> ) | 0.96       |               |            |               |      |     |
|   | $I_{spta}$ at $Z_{PII}$ or $Z_{SII}$       | (mW/cm <sup>2</sup> ) | 0.86       |               |            |               |      |     |
|   | pr at $Z_{PII}$                            | (MPa)                 | 3.61       |               |            |               |      |     |
| Operating control conditions  | B Frequency                                |                       | Level 1    | Level H0      |            | -             | N/A  |     |
|   | B Display Depth(mm)                        |                       | 10.00      | 50.00         |            | -             | N/A  |     |
|   | B Focus Pos(mm)                            |                       | 5.00       | 45.00         |            | -             | N/A  |     |
|   | B FOV                                      |                       | Small      | Small         |            | -             | N/A  |     |
|   | B Line Density                             |                       | Low        | Low           |            | -             | N/A  |     |
|   | PW Frequency                               |                       | Level 0    | Level 0       |            | Level 1       | N/A  |     |
|   | PW SV Depth(mm)                            |                       | 5.00       | 45.00         |            | 12.50         | N/A  |     |
|   | PW PRF(KHz)                                |                       | 0.90       | 1.50          |            | 0.90          | N/A  |     |
| <p>Note:</p> <p>1. (-) This index or parameter is not required for this operating mode.</p> <p>2. (N/A) This transducer is not intended for cephalic examination.</p> |  |                       |            |               |            |               |      |     |

## 2 Maximum Transducer Surface Temperature

In simulated use, the maximum surface temperatures of the transducers is:

- C5-2Q: 41.17 °C in B mode, 41.45 °C in PW/B+PW/B+C+PW mode.
- P5-1Q: 41.22°C in PW/B+PW/B+C+PW mode; 41.32°C in CW mode.
- E8-4Q: 41.28 °C in B mode, 41.17 °C in PW/B+PW/B+C+PW mode.

All other imaging modes and transducers have a steady-state surface temperature below 41°C.

### Uncertainty of temperature rise test:

Uncertainty of temperature rise test in simulate use:  $\bar{X}=7.73^{\circ}\text{C}$ ,  $U=0.26^{\circ}\text{C}$ ,  $K=2$ .

Uncertainty of temperature rise test in still air:  $\bar{X}=14.06^{\circ}\text{C}$ ,  $U=0.24^{\circ}\text{C}$ ,  $K=2$ .

The system limits patient contact temperature to 43°C, and the acoustic output below the maximum acoustic output limits for track 3. A power-protection circuit is used to prevent over-current conditions. If the power monitor protection circuit detects an over-current condition, then the drive current to the transducer is cut off promptly, preventing overheating of the transducer surface and limiting acoustic output. Validation of the power protection circuit is performed during normal operation. In single fault condition, when an abnormally large current or voltage is detected the system will automatically limit the current or voltage.



### 3 Formulas

Table 3-1 Generic Calculation Formulas

| No.                             | Generic Calculation items              | Formula  |
|---------------------------------|--|--|
| 1. B-mode Generic Calculations  |  |  |
| 1.1                             | Volume                                 | $\text{Volume}(\text{cm}^3) = \text{Pi} \times \text{D1}(\text{cm}) \times \text{D2}(\text{cm}) \times \text{D3}(\text{cm}) / 6$   |
| 1.2                             | Stenosis                               | $\% \text{Stenosis} =  (\text{D1} - \text{D2})  / \text{Max}(\text{D1}, \text{D2}) \times 100\%$<br>$\% \text{Stenosis} =  (\text{A1} - \text{A2})  / \text{Max}(\text{A1}, \text{A2}) \times 100\%$ |
| 2. Doppler Generic Calculations |  |  |
| 2.1                             | PG<br>(Pressure Gradient)              | $\text{PG} (\text{mmHg}) = 4 \times (\text{Vel}(\text{m/s})^2)$  |
| 2.2                             | RI<br>(Resistive Index)                | $\text{RI} = (\text{PS} - \text{ED}) / \text{PS}$  |
| 2.3                             | PI<br>(Pulse Index)                    | $\text{PI} = (\text{PS} - \text{ED}) / \text{TAMax}$   |
| 2.4                             | S/D                                    | $\text{S/D} = \text{PS} / \text{ED}$   |
| 2.5                             | HR<br>(Heart Rate)                     | $\text{HR} (\text{bpm}) = 60(\text{s}) \times \text{N}(\text{beats}) / \text{Time} (\text{s})$   |
| 2.6                             | $\Delta V$                             | $\Delta V = V2 - V1$   |
| 2.7                             | Acceleration                           | $\text{Accel} = (V2 - V1) / (T2 - T1)$   |
| 2.8                             | PHT<br>(Pressure Half Time)            | $\text{PHT} = (1 - 0.707) \times V1 \times (T2 - T1) / (V1 - V2)$  |
| 2.9                             | TAMax (Time Averaged Maximum Velocity) | $\text{TAMax} = \int_{Ta}^{Tb} V(t) dt / (Tb - Ta) (\text{cm/s or m/s})$   |
| 2.10                            | PGmax                                  | $\text{PGmax} = 4 \times (\text{PS}(\text{m/s})^2) (\text{mmHg})$  |
| 2.11                            | PGmean                                 | $\text{PGmean} = \int_{Ta}^{Tb} 4(V(t)(\text{m/s}))^2 dt / (Tb - Ta) (\text{mmHg})$  |
| 2.12                            | VTI<br>(Velocity-time Integral)        | $\text{VTI} = \int_{Ta}^{Tb} V(t) dt (\text{m})$   |

| No.                            | Generic Calculation items | Formula                                |
|--------------------------------|---------------------------|--|
| 3. M-mode Generic Calculations |                           |  |
| 3.1                            | Slope                     | Slope = Distance / Time                |
| 3.2                            | HR<br>(Heart Rate)        | HR (bpm) = 60(s) x N(beats) / Time (s) |

Table 3-2 Abdominal Calculation Formulas

| No. | Calculation Items | Description  | Formula  |
|-----|-------------------|--------------|--|
| 1   | Renal-Vol         | Renal Volume | Renal-Vol(cm <sup>3</sup> ) = 0.49×L(cm)×W(cm)×H(cm) |

Table 3-3 Gynecology Calculation Formulas

| No. | Calculation Items | Description                      | Formula   |
|-----|-------------------|----------------------------------|---|
| 1   | UT-Vol            | Uterus volume                    | UT-Vol(cm <sup>3</sup> ) = 0.523×UT-L(cm)×UT-W(cm)×UT-H(cm)   |
| 2   | UT-L/CX-L         | Uterus length /<br>Cervix length | UT-L/CX-L = UT-L(cm)/CX-L(cm)   |
| 3   | OV-Vol            | Ovary volume                     | OV-Vol(cm <sup>3</sup> ) =<br>0.523×OV-L(cm)×OV-W(cm)×OV-H(cm)  |
| 4   | Fol-Vol           | Follicle volume                  | Fol-Vol(ml) =<br>$\pi/6 \times \text{FOL-L(cm)} \times \text{FOL-W(cm)} \times \text{FOL-H(cm)}$  |
| 5   | Fol-Mean          | Follicle Mean<br>Diameter        | Fol.Mean(cm) = (sum of two distances)/2,<br>when measure any two of the three distances.<br><br>Fol.Mean(cm) =<br>$(\text{FOL-L(cm)} + \text{FOL-W(cm)} + \text{FOL-H(cm)})/3$ ,<br>when measure these three distances. |

Table 3-4 Obesteric Calculation Formulas

| No. | Calculation Items | Formula<br>(See Section 4 for references)   |
|-----|-------------------|---|
| 1   | GS GA             | Rempen(default), Hellman, Tokyo, China  |
| 2   | CRL GA            | Hadlock (default); Robinson, Hansmann, Tokyo, China   |
| 3   | BPD GA            | Hadlock (default),Merz, Rempen, Osaka, Tokyo, China   |
| 4   | HC GA             | Hadlock (default) , Merz  |
| 5   | AC GA             | Hadlock (default) , Merz  |
| 6   | FL GA             | Hadlock (default), Merz, Jeanty, Tokyo, Osaka, China  |
| 7   | HUM GA            | Jeanty  |
| 8   | FTA GA            | Osaka   |
| 9   | CER GA            | Goldstein   |
| 10  | THD GA            | Hansmann  |
| 11  | EFW               | Tokyo, Osaka, Hadlock 1, Hadlock 2, Hadlock 3, Hadlock 4, Shepard, Merz, Hansmann, Campbell |
| 12  | CUA               | Hadlock   |

Table 3-5 Cardiac Calculation Formulas

| No. | Calculation Items | Description | Formula              |  |
|-----|-------------------|-------------|----------------------|--|
| 1   | LV Simpson        | SV(A4C)     | Stroke Volume        | $SV(ml) = EDV(ml) - ESV(ml)$               |
|     |                   | EF(A4C)     | Ejection Fraction    | $EF = SV(ml) / EDV(ml)$                    |
|     |                   | CO(A4C)     | Cardiac Output       | $CO(l/min) = SV(ml) \times HR(bpm) / 1000$ |
|     |                   | CI(A4C)     | Cardiac Output Index | $CI = CO(l/min) / BSA(m^2)$                |
|     |                   | SI(A4C)     | Stroke Volume Index  | $SI= SV(ml) / BSA(m^2)$                    |
|     |                   | SV(A2C)     | Stroke Volume        | $SV(ml) = EDV(ml) - ESV(ml)$               |
|     |                   | EF(A2C)     | Ejection Fraction    | $EF = SV(ml) / EDV(ml)$                    |

| No. | Calculation Items                |           | Description                              | Formula   |
|-----|----------------------------------|-----------|--|---|
|     |                                  | CO(A2C)   | Cardiac Output                           | $CO(l/min) = SV(ml) \times HR(bpm) / 1000$  |
|     |                                  | CI(A2C)   | Cardiac Output Index                     | $CI = CO(l/min) / BSA(m^2)$   |
|     |                                  | SI(A2C)   | Stroke Volume Index                      | $SI = SV(ml) / BSA(m^2)$  |
|     |                                  | EDV(BP)   | End-diastole Left Ventricular Volume     | See table 3-6   |
|     |                                  | ESV(BP)   | End-systole Left Ventricular Volume      |   |
|     |                                  | SV(BP)    | Stroke Volume                            | $SV(ml) = EDV(ml) - ESV(ml)$  |
|     |                                  | CO(BP)    | Cardiac Output                           | $CO(l/min) = SV(ml) \times HR(bpm) / 1000$  |
|     |                                  | EF(BP)    | Ejection Fraction                        | $EF = SV(ml) / EDV(ml)$   |
|     |                                  | SI(BP)    | Stroke Volume Index                      | $SI = SV(ml) / BSA(m^2)$  |
|     |                                  | CI(BP)    | Cardiac Output Index                     | $CI = CO(l/min) / BSA(m^2)$   |
| 2   | Mitral Valve                     | E/A       | E-wave Velocity/ A-wave Velocity         | $E/A = E \text{ Vel}(cm/s) / A \text{ Vel}(cm/s)$   |
| 3   | Mitral Valve                     | MV Area   | Mitral Valve Area                        | $PHT(ms) = \frac{(1-0.707) \times V1(cm/s) \times \text{Time}(ms)}{(V1(cm/s) - V2(cm/s))}$ $MV \text{ Area}(cm^2) = 220 / MV \text{ PHT}(ms)$ |
| 4   | P Vein                           | PVein S/D | Pulmonic Veins Systole/Diastole Velocity | $S/D = S \text{ Vel}(cm/s) / D \text{ Vel}(cm/s)$   |
| 5   | Vent. Dim (Ventricular Diameter) | EDV       | End-diastolic Left Ventricular           | see table 6-3   |
|     |                                  | ESV       | End-systolic Left Ventricular            |   |
|     |                                  | SV        | Stroke Volume                            | $SV(ml) = EDV(ml) - ESV(ml)$  |
|     |                                  | CO        | Cardiac Output                           | $CO(l/min) = SV(ml) \times HR(bpm) / 1000$  |

| No. | Calculation Items |         | Description                                       | Formula  |
|-----|-------------------|---------|---|--|
|     |                   | EF      | Ejection Fraction                                 | EF(no unit) = SV(ml) / EDV(ml)                 |
|     |                   | SI      | Stroke Volume Index                               | SI(no unit) = SV(ml) / BSA(m <sup>2</sup> )    |
|     |                   | CI      | Cardiac Output Index                              | CI(no unit) = CO(l/min) / BSA(m <sup>2</sup> ) |
|     |                   | MVCF    | Mean Velocity of Circumferential Fiber Shortening | MVCF = (LVIDd - LVIDs)/(LVIDd × LVET(sec))     |
|     |                   | FS      | Fractional Shortening                             | FS(no unit) = (LVIDd - LVIDs) / LVIDd          |
| 6   | LA/Ao             | LAD/AoD | Left Atrial Diameter/ Aortic Toot Diameter        | LA/Ao (no unit) = LAD(cm) / AoD(cm)            |

Table 3-6 EDV and ESV Calculation Formulas

| Calc           | Input | Formula   |
|----------------|-------|---|
| EDV A4C        | LVLd  | $EDV4[ml] = \pi \times LVLd_{4i}[cm] / 20 \times \sum_{i=1}^{20} r_{4i}^2[cm]$  |
| ESV A4C        | LVLs  | $ESV4[ml] = \pi \times LVLs_{4i}[cm] / 20 \times \sum_{i=1}^{20} r_{4i}^2[cm]$  |
| EDV A2C        | LVLd  | $EDV2[ml] = \pi \times LVLd_{2i}[cm] / 20 \times \sum_{i=1}^{20} r_{2i}^2[cm]$  |
| ESV A2C        | LVLs  | $ESV2[ml] = \pi \times LVLs_{2i}[cm] / 20 \times \sum_{i=1}^{20} r_{2i}^2[cm]$  |
| EDV (BP)       | LVLd  | $EDV[ml] = \pi \times MAX\{LVLd_{2i}[cm], LVLd_{4i}[cm]\} / 20 \times \sum_{i=1}^{20} (r_{2i}[cm] \times r_{4i}[cm])$ |
| ESV (BP)       | LVLs  | $ESV[ml] = \pi \times MAX\{LVLs_{2i}[cm], LVLs_{4i}[cm]\} / 20 \times \sum_{i=1}^{20} (r_{2i}[cm] \times r_{4i}[cm])$ |
| EDV(Teichholz) | LVIDd | $EDV(ml) = (7 \times (LVIDd(cm))^3) / (2.4 + LVIDd(cm))$  |
| ESV(Teichholz) | LVIDs | $ESV(ml) = (7 \times (LVIDs(cm))^3) / (2.4 + LVIDs(cm))$  |
| EDV(Cube)      | LVIDd | $EDV(ml) = LVIDd(cm)^3$   |
| ESV(Cube)      | LVIDs | $ESV(ml) = LVIDs(cm)^3$   |

|             |       |  |
|-------------|-------|--|
| EDV(Gibson) | LVIDd | $EDV(ml) = \frac{\pi}{6} \times (0.98 \times LVIDd(cm) + 5.90) \times LVIDd(cm)^2$ |
| ESV(Gibson) | LVIDs | $ESV(ml) = \frac{\pi}{6} \times (1.14 \times LVIDs(cm) + 4.18) \times LVIDs(cm)^2$ |

Table 3-7 Small Parts Calculation Formulas

| No. | Calculation items | Description    | Formula  |
|-----|-------------------|----------------|--|
| 1   | THY-Vol           | Thyroid volume | $THY-Vol(cm^3) = 0.479 \times L(cm) \times W(cm) \times H(cm)$ |

Table 3-8 Urology Calculation Formulas

| No. | Calculation items | Description              | Formula  |
|-----|-------------------|--------------------------|--|
| 1   | Renal-Vol         | Renal Volume             | $Renal-Vol(cm^3) = 0.49 \times L(cm) \times W(cm) \times H(cm)$                    |
| 2   | Pre-BL Vol        | Pre-void Bladder Volume  | $Pre-BL Vol(ml) = \pi/6 \times L(cm) \times W(cm) \times H(cm)$                    |
| 3   | Post-BL Vol       | Post-void Bladder Volume | $Post-BL Vol(ml) = \pi/6 \times L(cm) \times W(cm) \times H(cm)$                   |
| 4   | Mictur. Vol       | Micturated Volume        | $Mictur. Vol(ml) = (Pre-BL Vol) - (Post-BL Vol)$                                   |
| 5   | Prostate-Vol      | Prostate Volume          | $Prostate -Vol(cm^3) = 0.52 \times Pros-L(cm) \times Pros-W(cm) \times Pros-H(cm)$ |
| 6   | Testis-Vol        | Testicle Volume          | $Testis-Vol(cm^3) = 0.65 \times L(cm) \times W(cm) \times H(cm)$                   |

Table 3-7 Vascular Calculation Formulas

| No. | Calculation items    | Formula  |
|-----|----------------------|--|
| 1   | Volume Flow Area     | $Volume Flow Area = \pi * (VF Diam (cm)/2)^2$                        |
| 2   | ICA/CCA              | $ICA/CCA = ICA PS / CCA PS$  |
| 3   | Volume Flow (TAMean) | $Volume Flow (TAMean) = VF Area (cm^2) *  VF TAMean  (cm/s) * 60(s)$ |
| 4   | Volume Flow(TAMax)   | $Volume Flow(TAMax) = VF Area (cm^2) *  VF TAMax  (cm/s) * 60(s)$    |

## 4 Obstetrical References

### 4.1. Application Table of Obstetrical Reference Formulas

| Parameter  | Formula   | Measurement range (mm) | MA range      | $\pm 2$ SD  |
|------------|-----------|------------------------|---------------|---|
| <b>GS</b>  | Tokyo     | [10, 68]               | 4w0d ~ 12w1d  | See table GS, Tokyo   |
|            | Hellman   | [17, 60]               | 6w0d ~ 12w1d  | 0   |
|            | Rempen    | [2, 73]                | 4w6d ~ 14w1d  | $\pm 12$ days<br>See table GS, Rempen for details   |
|            | China     | [10, 68]               | 5w0d ~ 12w0d  | See table GS, China   |
| <b>CRL</b> | Tokyo     | [6, 100]               | 6w3d ~ 16w0d  | See table CRL, Tokyo  |
|            | Hadlock   | [2, 121.1]             | 5w5d ~ 18w0d  | 8.826%  |
|            | Robinson  | [6.7, 82.4]            | 6w3d ~ 13w6d  | $\pm 5$ days  |
|            | Hansmann  | [6, 150]               | 6w1d ~ 21w3d  | See table CRL, Hansmann   |
|            | China     | [9, 105]               | 7w0d ~ 17w0d  | See table CRL, China  |
| <b>BPD</b> | Tokyo     | [16, 92]               | 11w3d ~ 40w0d | See table BPD, Tokyo  |
|            | Hadlock   | [15, 102]              | 12w1d ~ 42w1d | 12-18 wk $\pm 1.19$ wk (8 days)<br>18-24 wk $\pm 1.73$ wk (12 days)<br>24-30 wk $\pm 2.18$ wk (15 days)<br>30-36 wk $\pm 3.08$ wk (22 days)<br>36-42 wk $\pm 3.20$ wk (22 days) |
|            | Merz      | [21, 102]              | 12w1d ~ 40w2d | See table BPD, Merz   |
|            | Rempen    | [3, 27]                | 6w6d ~ 13w5d  | $\pm 10$ days<br>See table BPD, Rempen for details  |
|            | Osaka     | [13.3, 93.6]           | 10w0d ~ 40w0d | See table BPD, Osaka  |
|            | China     | [19, 94]               | 12w0d ~ 40w0d | See table BPD, China  |
|            | <b>HC</b> | Hadlock                | [56, 358]     | 12w0d ~ 41w6d   |
| Merz       |           | [72, 364]              | 12w1d ~ 40w4d | See table HC, Merz  |
| <b>AC</b>  | Hadlock   | [50, 381]              | 11w6d ~ 41w6d | 12-18 wk $\pm 1.66$ wk (12 days)  |

|            |           |                                |               |  |
|------------|-----------|--------------------------------|---------------|--|
|            |           |                                |               | 18-24 wk ± 2.06 wk (14 days)<br>24-30 wk ± 2.18 wk (15 days)<br>30-36 wk ± 2.96 wk (21 days)<br>36-42 wk ± 3.04 wk (19 days)                                 |
|            | Merz      | [56, 348]                      | 12w1d ~ 39w6d | See table AC, Merz   |
| <b>FL</b>  | Tokyo     | [8, 72]                        | 12w3d ~ 40w2d | See table FL, Tokyo  |
|            | Hadlock   | [7, 82]                        | 12w1d ~ 42w0d | 12-18 wk ± 1.38 wk (10 days)<br>18-24 wk ± 1.80 wk (13 days)<br>24-30 wk ± 2.08 wk (15 days)<br>30-36 wk ± 2.96 wk (21 days)<br>36-42 wk ± 3.12 wk (22 days) |
|            | Jeanty    | [10, 80]                       | 12w4d ~ 40w0d | ±19 days   |
|            | Merz      | [10, 80]                       | 12w2d ~ 40w1d | See table FL, Merz   |
|            | Osaka     | [9.4, 71.2]                    | 13w0d ~ 40w0d | See table FL, Osaka  |
|            | China     | [6, 75]                        | 12w4d ~ 40w2d | See table FL, China  |
| <b>HUM</b> | Jeanty    | [9, 69]                        | 12w0d ~ 40w0d | ±23 days (±3.3104 wks)   |
| <b>FTA</b> | Osaka     | [5.6, 86.6] (cm <sup>2</sup> ) | 14w0d ~ 40w0d | See table FTA, Osaka   |
| <b>CER</b> | Goldstein | [14, 52] mm                    | /             | /  |
| <b>THD</b> | Hansmann  | [20, 105] mm                   | /             | /  |

## 4.2. GS

### Hellman:

Hellman LM, Kobayashi M, Fillisti L et al. "Growth and development of the human fetus prior to the 20<sup>th</sup> week of gestation." Am J Obstetrics Gynecology 103:789, 1969

$$MA (GS \text{ mm}) = (GS + 25.43) / 7.02$$

### Rempen:

Rempen A. "Biometrie in der Frühgravidität" (I. Trimenon) (Biometry in Early Pregnancy (1<sup>st</sup> Trimester))." Der Frauenarzt 32:425, 1991

Table GS, Rempen

| GS mm | MA   | +/- 2SD | GS mm | MA   | +/- 2SD | GS mm | MA   | +/- 2SD | GS mm | MA    | +/- 2SD |
|-------|------|---------|-------|------|---------|-------|------|---------|-------|-------|---------|
| 02.0  | 4w6d | 12      | 20.0  | 6w6d | 12      | 38.0  | 9w1d | 12      | 56.0  | 11w4d | 12      |
| 03.0  | 5w0d | 12      | 21.0  | 7w0d | 12      | 39.0  | 9w2d | 12      | 57.0  | 11w5d | 12      |
| 04.0  | 5w1d | 12      | 22.0  | 7w1d | 12      | 40.0  | 9w3d | 12      | 58.0  | 11w6d | 12      |
| 05.0  | 5w1d | 12      | 23.0  | 7w2d | 12      | 41.0  | 9w4d | 12      | 59.0  | 12w0d | 12      |
| 06.0  | 5w2d | 12      | 24.0  | 7w3d | 12      | 42.0  | 9w5d | 12      | 60.0  | 12w1d | 12      |



|      |      |    |      |      |    |      |       |    |      |       |    |
|------|------|----|------|------|----|------|-------|----|------|-------|----|
| 07.0 | 5w3d | 12 | 25.0 | 7w4d | 12 | 43.0 | 9w6d  | 12 | 61.0 | 12w2d | 12 |
| 08.0 | 5w4d | 12 | 26.0 | 7w4d | 12 | 44.0 | 9w6d  | 12 | 62.0 | 12w3d | 12 |
| 09.0 | 5w5d | 12 | 27.0 | 7w5d | 12 | 45.0 | 10w0d | 12 | 63.0 | 12w4d | 12 |
| 10.0 | 5w5d | 12 | 28.0 | 7w6d | 12 | 46.0 | 10w1d | 12 | 64.0 | 12w5d | 12 |
| 11.0 | 5w6d | 12 | 29.0 | 8w0d | 12 | 47.0 | 10w2d | 12 | 65.0 | 12w6d | 12 |
| 12.0 | 6w0d | 12 | 30.0 | 8w1d | 12 | 48.0 | 10w3d | 12 | 66.0 | 13w0d | 12 |
| 13.0 | 6w1d | 12 | 31.0 | 8w2d | 12 | 49.0 | 10w4d | 12 | 67.0 | 13w1d | 12 |
| 14.0 | 6w2d | 12 | 32.0 | 8w3d | 12 | 50.0 | 10w5d | 12 | 68.0 | 13w2d | 12 |
| 15.0 | 6w2d | 12 | 33.0 | 8w3d | 12 | 51.0 | 10w6d | 12 | 69.0 | 13w3d | 12 |
| 16.0 | 6w3d | 12 | 34.0 | 8w4d | 12 | 52.0 | 11w0d | 12 | 70.0 | 13w4d | 12 |
| 17.0 | 6w4d | 12 | 35.0 | 8w5d | 12 | 53.0 | 11w1d | 12 | 71.0 | 13w5d | 12 |
| 18.0 | 6w5d | 12 | 36.0 | 8w6d | 12 | 54.0 | 11w2d | 12 | 72.0 | 14w0d | 12 |
| 19.0 | 6w6d | 12 | 37.0 | 9w0d | 12 | 55.0 | 11w3d | 12 | 73.0 | 14w1d | 12 |

**Tokyo:**

Studies on Fetal Growth and Functional Developments, Takashi Okai, Department of Obstetrics and Gynecology, Faculty of Medicine, University of Tokyo

Table GS, **Tokyo**

| GS cm | MA   | +/- 2SD | GS cm | MA   | +/- 2SD | GS cm | MA    | +/- 2SD | GS cm | MA    | +/- 2SD |
|-------|------|---------|-------|------|---------|-------|-------|---------|-------|-------|---------|
| 1     | 4w0d | 7       | 2.6   | 6w6d | 12      | 4.2   | 9w1d  | 14      | 5.8   | 11w1d | 16      |
| 1.2   | 4w1d | 7       | 2.8   | 7w1d | 12      | 4.4   | 9w3d  | 14      | 6     | 11w3d | 16      |
| 1.4   | 4w4d | 7       | 3     | 7w3d | 12      | 4.6   | 9w4d  | 14      | 6.2   | 11w4d | 16      |
| 1.6   | 5w0d | 8       | 3.2   | 7w4d | 12      | 4.8   | 10w0d | 15      | 6.4   | 11w6d | 16      |
| 1.8   | 5w1d | 8       | 3.4   | 8w0d | 13      | 5     | 10w1d | 15      | 6.6   | 11w6d | 16      |
| 2     | 5w4d | 8       | 3.6   | 8w1d | 13      | 5.2   | 10w3d | 15      | 6.8   | 12w1d | 17      |
| 2.2   | 6w0d | 11      | 3.8   | 8w3d | 13      | 5.4   | 10w4d | 15      |       |       |         |
| 2.4   | 6w1d | 11      | 4     | 8w6d | 13      | 5.6   | 10w6d | 15      |       |       |         |

**China:**

Wu Zhongyu, "Ultrasound Diagnosis in Obstetrics and Gynecology", Tianjin Science and Technology Publisher, 1995

Table GS, **China**

| GS cm | MA   | +/- 2SD | GS cm | MA   | +/- 2SD | GS cm | MA   | +/- 2SD | GS cm | MA    | +/- 2SD |
|-------|------|---------|-------|------|---------|-------|------|---------|-------|-------|---------|
| 1     | 5w0d | 4       | 2.5   | 6w6d | 7       | 4     | 8w3d | 11      | 5.5   | 10w3d | 12      |
| 1.1   | 5w1d | 5       | 2.6   | 7w0d | 7       | 4.1   | 8w4d | 11      | 5.6   | 10w4d | 12      |
| 1.2   | 5w2d | 5       | 2.7   | 7w0d | 7       | 4.2   | 8w5d | 11      | 5.7   | 10w5d | 12      |
| 1.3   | 5w3d | 5       | 2.8   | 7w1d | 8       | 4.3   | 8w6d | 12      | 5.8   | 10w5d | 12      |
| 1.4   | 5w4d | 5       | 2.9   | 7w2d | 8       | 4.4   | 9w0d | 12      | 5.9   | 10w6d | 12      |
| 1.5   | 5w5d | 5       | 3     | 7w3d | 8       | 4.5   | 9w1d | 12      | 6     | 11w0d | 12      |

|     |      |   |     |      |    |     |       |    |     |       |    |
|-----|------|---|-----|------|----|-----|-------|----|-----|-------|----|
| 1.6 | 5w6d | 5 | 3.1 | 7w4d | 8  | 4.6 | 9w2d  | 12 | 6.1 | 11w1d | 12 |
| 1.7 | 6w0d | 6 | 3.2 | 7w4d | 9  | 4.7 | 9w3d  | 12 | 6.2 | 11w2d | 13 |
| 1.8 | 6w0d | 6 | 3.3 | 7w5d | 9  | 4.8 | 9w4d  | 12 | 6.3 | 11w3d | 13 |
| 1.9 | 6w1d | 6 | 3.4 | 7w6d | 9  | 4.9 | 9w4d  | 12 | 6.4 | 11w4d | 13 |
| 2   | 6w2d | 6 | 3.5 | 8w0d | 9  | 5   | 9w5d  | 12 | 6.5 | 11w5d | 13 |
| 2.1 | 6w3d | 6 | 3.6 | 8w0d | 10 | 5.1 | 9w6d  | 12 | 6.6 | 11w5d | 13 |
| 2.2 | 6w4d | 6 | 3.7 | 8w1d | 10 | 5.2 | 10w0d | 12 | 6.7 | 11w6d | 13 |
| 2.3 | 6w4d | 6 | 3.8 | 8w2d | 10 | 5.3 | 10w1d | 12 | 6.8 | 12w0d | 13 |
| 2.4 | 6w5d | 7 | 3.9 | 8w3d | 10 | 5.4 | 10w2d | 12 |     |       |    |

### 4.3. CRL

#### Hadlock:

Hadlock FP, Shah YP, Kanon DJ etc. "Fetal Crown-Rump Length: Reevaluation of Relation to Menstrual Age (5-18 weeks) with High-Resolution Real-Time US." Radiology 182(2):501, 1992

MA (CRL mm) =  $\exp(1.684969 + 0.0315646 \cdot \text{CRL} - 0.00049306 \cdot \text{CRL}^2 + 0.000004057 \cdot \text{CRL}^3 - 0.0000000120456 \cdot \text{CRL}^4)$

#### Robinson:

Robinson HP and Fleming JEE. "A critical evaluation of sonar 'crown-rump length' measurements." British Journal of Obstetrics and Gynecology 82:702, 1975

MA =  $(8.052 \cdot \text{CRL}^{1/2} + 23.73) / 7$

#### Hansmann:

Hansmann M, Hackelöer B-J, Staudach A. Ultrasound Diagnosis in Obstetrics and Gynecology. New York: Spring-Verlag, 1985, P. 439

Table CRL, Hansmann

| CRL mm | MA   | +/- 2SD | CRL mm | MA    | +/- 2SD | CRL mm | MA    | +/- 2SD | CRL mm | MA    | +/- 2SD |
|--------|------|---------|--------|-------|---------|--------|-------|---------|--------|-------|---------|
| 6.0    | 6w1d | 6       | 22.0   | 9w1d  | 7       | 52.0   | 12w2d | 9       | 100.0  | 15w5d | 12      |
| 7.0    | 6w2d | 7       | 23.0   | 9w2d  | 7       | 54.0   | 12w3d | 9       | 103.0  | 16w0d | 13      |
| 8.0    | 6w4d | 6       | 24.0   | 9w3d  | 7       | 56.0   | 12w4d | 9       | 106.0  | 16w2d | 13      |
| 9.0    | 6w6d | 7       | 26.0   | 9w5d  | 7       | 58.0   | 12w5d | 9       | 110.0  | 16w4d | 14      |
| 10.0   | 7w0d | 7       | 28.0   | 10w0d | 7       | 60.0   | 12w6d | 9       | 113.0  | 17w0d | 14      |
| 11.0   | 7w2d | 6       | 30.0   | 10w2d | 7       | 63.0   | 13w0d | 10      | 116.0  | 17w2d | 14      |
| 12.0   | 7w3d | 7       | 32.0   | 10w3d | 8       | 66.0   | 13w2d | 10      | 120.0  | 17w4d | 14      |
| 13.0   | 7w4d | 7       | 34.0   | 10w5d | 7       | 70.0   | 13w3d | 11      | 123.0  | 18w0d | 14      |
| 14.0   | 7w6d | 7       | 36.0   | 10w6d | 8       | 73.0   | 13w5d | 10      | 126.0  | 18w2d | 15      |
| 15.0   | 8w0d | 7       | 38.0   | 11w1d | 8       | 76.0   | 13w6d | 11      | 130.0  | 18w6d | 14      |
| 16.0   | 8w2d | 6       | 40.0   | 11w2d | 8       | 80.0   | 14w1d | 11      | 133.0  | 19w1d | 15      |
| 17.0   | 8w3d | 6       | 42.0   | 11w3d | 8       | 83.0   | 14w2d | 12      | 136.0  | 19w4d | 16      |
| 18.0   | 8w4d | 7       | 44.0   | 11w4d | 9       | 86.0   | 14w4d | 12      | 140.0  | 20w0d | 16      |

|      |      |   |      |       |   |      |       |    |       |       |    |
|------|------|---|------|-------|---|------|-------|----|-------|-------|----|
| 19.0 | 8w5d | 7 | 46.0 | 11w6d | 8 | 90.0 | 14w6d | 12 | 143.0 | 20w3d | 16 |
| 20.0 | 8w6d | 7 | 48.0 | 12w0d | 9 | 93.0 | 15w1d | 12 | 146.0 | 20w6d | 16 |
| 21.0 | 9w0d | 7 | 50.0 | 12w1d | 9 | 96.0 | 15w3d | 12 | 150.0 | 21w3d | 16 |

**Tokyo:**

Studies on Fetal Growth and Functional Developments, Takashi Okai, Department of Obstetrics and Gynecology, Faculty of Medicine, University of Tokyo

Table CRL, Tokyo

| CRL cm | MA    | +/- 2SD | CRL cm | MA    | +/- 2SD | CRL cm | MA    | +/- 2SD | CRL cm | MA    | +/- 2SD |
|--------|-------|---------|--------|-------|---------|--------|-------|---------|--------|-------|---------|
| 0.6    | 6w3d  | 7       | 3      | 10w3d | 7       | 5.4    | 12w4d | 7       | 7.8    | 14w3d | 8       |
| 0.8    | 6w6d  | 7       | 3.2    | 10w4d | 7       | 5.6    | 12w5d | 7       | 8      | 14w4d | 8       |
| 1      | 7w1d  | 7       | 3.4    | 10w6d | 7       | 5.8    | 13w0d | 7       | 8.2    | 14w5d | 8       |
| 1.2    | 7w4d  | 7       | 3.6    | 11w0d | 7       | 6      | 13w1d | 7       | 8.4    | 14w6d | 8       |
| 1.4    | 7w6d  | 7       | 3.8    | 11w1d | 7       | 6.2    | 13w2d | 7       | 8.6    | 15w0d | 14      |
| 1.6    | 8w1d  | 7       | 4      | 11w3d | 7       | 6.4    | 13w3d | 7       | 8.8    | 15w1d | 14      |
| 1.8    | 8w4d  | 7       | 4.2    | 11w4d | 7       | 6.6    | 13w4d | 7       | 9      | 15w2d | 14      |
| 2      | 9w1d  | 7       | 4.4    | 11w6d | 7       | 6.8    | 13w5d | 7       | 9.2    | 15w3d | 14      |
| 2.2    | 9w2d  | 7       | 4.6    | 12w0d | 7       | 7      | 13w6d | 7       | 9.4    | 15w4d | 14      |
| 2.4    | 9w4d  | 7       | 4.8    | 12w1d | 7       | 7.2    | 14w0d | 7       | 9.6    | 15w5d | 14      |
| 2.6    | 9w6d  | 7       | 5      | 12w2d | 7       | 7.4    | 14w1d | 7       | 9.8    | 15w6d | 14      |
| 2.8    | 10w2d | 7       | 5.2    | 12w3d | 7       | 7.6    | 14w2d | 7       | 10     | 16w0d | 14      |

**China:**

Wu Zhongyu, "Ultrasound Diagnosis in Obstetrics and Gynecology", Tianjin Science and Technology Publisher, 1995

Table CRL, China

| CRL cm | MA   | +/- 2SD | CRL cm | MA    | +/- 2SD |     |       |    | CRL cm | MA    | +/- 2SD |
|--------|------|---------|--------|-------|---------|-----|-------|----|--------|-------|---------|
| 0.9    | 7w0d | 6       | 3.4    | 10w3d | 7       | 5.9 | 12w6d | 10 | 8.4    | 15w1d | 12      |
| 1      | 7w1d | 6       | 3.5    | 10w4d | 7       | 6   | 13w0d | 10 | 8.5    | 15w1d | 13      |
| 1.1    | 7w2d | 6       | 3.6    | 10w5d | 7       | 6.1 | 13w0d | 10 | 8.6    | 15w2d | 13      |
| 1.2    | 7w3d | 6       | 3.7    | 10w5d | 7       | 6.2 | 13w1d | 10 | 8.7    | 15w2d | 13      |
| 1.3    | 7w4d | 6       | 3.8    | 10w6d | 7       | 6.3 | 13w2d | 11 | 8.8    | 15w3d | 13      |
| 1.4    | 7w5d | 6       | 3.9    | 11w0d | 7       | 6.4 | 13w2d | 11 | 8.9    | 15w4d | 13      |
| 1.5    | 7w6d | 6       | 4      | 11w1d | 8       | 6.5 | 13w3d | 11 | 9      | 15w4d | 13      |
| 1.6    | 8w0d | 6       | 4.1    | 11w1d | 8       | 6.6 | 13w3d | 11 | 9.1    | 15w5d | 13      |
| 1.7    | 8w1d | 6       | 4.2    | 11w2d | 8       | 6.7 | 13w4d | 11 | 9.2    | 15w6d | 13      |
| 1.8    | 8w2d | 6       | 4.3    | 11w3d | 8       | 6.8 | 13w5d | 11 | 9.3    | 15w6d | 13      |
| 1.9    | 8w3d | 6       | 4.4    | 11w4d | 8       | 6.9 | 13w5d | 11 | 9.4    | 16w0d | 13      |
| 2      | 8w4d | 6       | 4.5    | 11w4d | 8       | 7   | 13w6d | 11 | 9.5    | 16w1d | 13      |

|     |       |   |     |       |    |     |       |    |      |       |    |
|-----|-------|---|-----|-------|----|-----|-------|----|------|-------|----|
| 2.1 | 8w5d  | 6 | 4.6 | 11w5d | 8  | 7.1 | 14w0d | 11 | 9.6  | 16w1d | 13 |
| 2.2 | 8w6d  | 6 | 4.7 | 11w6d | 9  | 7.2 | 14w0d | 12 | 9.7  | 16w2d | 14 |
| 2.3 | 9w0d  | 6 | 4.8 | 11w6d | 9  | 7.3 | 14w1d | 12 | 9.8  | 16w3d | 14 |
| 2.4 | 9w1d  | 6 | 4.9 | 12w0d | 9  | 7.4 | 14w1d | 12 | 9.9  | 16w3d | 14 |
| 2.5 | 9w2d  | 6 | 5   | 12w0d | 9  | 7.5 | 14w2d | 12 | 10   | 16w4d | 14 |
| 2.6 | 9w3d  | 6 | 5.1 | 12w1d | 9  | 7.6 | 14w3d | 12 | 10.1 | 16w5d | 14 |
| 2.7 | 9w4d  | 7 | 5.2 | 12w2d | 9  | 7.7 | 14w3d | 12 | 10.2 | 16w6d | 14 |
| 2.8 | 9w5d  | 7 | 5.3 | 12w2d | 9  | 7.8 | 14w4d | 12 | 10.3 | 16w6d | 14 |
| 2.9 | 9w6d  | 7 | 5.4 | 12w3d | 9  | 7.9 | 14w5d | 12 | 10.4 | 17w0d | 14 |
| 3   | 10w0d | 7 | 5.5 | 12w3d | 9  | 8   | 14w5d | 12 | 10.5 | 17w0d | 14 |
| 3.1 | 10w1d | 7 | 5.6 | 12w4d | 9  | 8.1 | 14w6d | 12 |      |       |    |
| 3.2 | 10w2d | 7 | 5.7 | 12w5d | 10 | 8.2 | 15w0d | 12 |      |       |    |
| 3.3 | 10w3d | 7 | 5.8 | 12w5d | 10 | 8.3 | 15w0d | 12 |      |       |    |

#### 4.4. BPD

##### Hadlock:

Hadlock FP, Deter RL etc. "Estimation Fetal Age: Computer-Assisted Analysis of Multiple Fetal Growth Parameters." Radiology 152:497, 1984

$$\text{MA (BPD cm)} = 9.54 + 1.482 * (\text{BPD}) + 0.1676 * (\text{BPD}^2)$$

##### Merz:

Merz E. Ultrasound in Gynecology and Obstetrics. Stuttgart and New York: Thieme Medical Publishers, Inc., 1991, p. 326

Table **BPD**, Merz

| BPD mm | MA    | +/- 2SD | BPD mm | MA   | +/- 2SD | BPD mm | MA    | +/- 2SD | BPD mm | MA    | +/- 2SD |
|--------|-------|---------|--------|------|---------|--------|-------|---------|--------|-------|---------|
| 21.0   | 12w1d | 13      | 41.0   | 17w5 | 16      | 61.0   | 23w6d | 17      | 82.0   | 31w2d | 19      |
| 22.0   | 12w3d | 12      | 42.0   | 18w0 | 16      | 62.0   | 24w1d | 17      | 83.0   | 31w5d | 18      |
| 23.0   | 12w5d | 12      | 43.0   | 18w2 | 16      | 63.0   | 24w4d | 17      | 84.0   | 32w1d | 18      |
| 24.0   | 13w0d | 13      | 44.0   | 18w4 | 16      | 64.0   | 24w6d | 17      | 85.0   | 32w4d | 18      |
| 25.0   | 13w1d | 13      | 45.0   | 18w6 | 16      | 65.0   | 25w1d | 17      | 86.0   | 32w6d | 19      |
| 26.0   | 13w4d | 12      | 46.0   | 19w1 | 13      | 66.0   | 25w4d | 17      | 87.0   | 33w2d | 19      |
| 27.0   | 13w6d | 13      | 47.0   | 19w3 | 15      | 67.0   | 25w6d | 17      | 89.0   | 34w1d | 21      |
| 28.0   | 14w1d | 13      | 48.0   | 19w5 | 16      | 68.0   | 26w1d | 18      | 90.0   | 34w4d | 19      |
| 29.0   | 14w2d | 13      | 49.0   | 20w0 | 16      | 69.0   | 26w4d | 17      | 91.0   | 35w1d | 19      |
| 30.0   | 14w4d | 13      | 50.0   | 20w3 | 15      | 70.0   | 26w6d | 17      | 92.0   | 35w4d | 19      |
| 31.0   | 14w6d | 15      | 51.0   | 20w5 | 16      | 71.0   | 27w1d | 18      | 93.0   | 35w6d | 19      |
| 32.0   | 15w1d | 15      | 52.0   | 21w0 | 16      | 72.0   | 27w4d | 18      | 94.0   | 36w3d | 21      |
| 33.0   | 15w3d | 13      | 53.0   | 21w2 | 16      | 73.0   | 27w6d | 18      | 95.0   | 36w6d | 21      |
| 34.0   | 15w5d | 15      | 54.0   | 21w4 | 17      | 74.0   | 28w2d | 18      | 96.0   | 37w2d | 21      |

|      |       |    |      |      |    |      |       |    |       |       |    |
|------|-------|----|------|------|----|------|-------|----|-------|-------|----|
| 35.0 | 16w0d | 15 | 55.0 | 21w6 | 17 | 75.0 | 28w4d | 18 | 97.0  | 37w6d | 19 |
| 36.0 | 16w2d | 15 | 56.0 | 22w1 | 17 | 76.0 | 29w0d | 18 | 98.0  | 38w2d | 21 |
| 37.0 | 16w4d | 13 | 57.0 | 22w3 | 16 | 77.0 | 29w3d | 18 | 99.0  | 38w6d | 19 |
| 38.0 | 16w6d | 15 | 58.0 | 22w6 | 16 | 78.0 | 29w6d | 18 | 100.0 | 39w2d | 22 |
| 39.0 | 17w1d | 15 | 59.0 | 23w1 | 17 | 79.0 | 30w1d | 18 | 101.0 | 39w6d | 21 |
| 40.0 | 17w3d | 15 | 60.0 | 23w4 | 17 | 81.0 | 30w6d | 19 | 102.0 | 40w2d | 22 |

**Rempen:**

Rempen A. "Biometrie in der Frühgravidität" (I. Trimenon) (Biometry in Early Pregnancy (1<sup>st</sup> Trimester))." Der Frauenarzt 32:425, 1991

Table **BPD**, Rempen

| BPD<br>mm | MA   | +/-<br>2SD | BPD<br>mm | MA    | +/-<br>2SD | BPD<br>mm | MA    | +/-<br>2SD | BPD<br>mm | MA    | +/-<br>2SD |
|-----------|------|------------|-----------|-------|------------|-----------|-------|------------|-----------|-------|------------|
| 03.0      | 6w6d | 10         | 10.0      | 8w6d  | 10         | 17.0      | 10w6d | 10         | 24.0      | 12w6d | 10         |
| 04.0      | 7w1d | 10         | 11.0      | 9w1d  | 10         | 18.0      | 11w1d | 10         | 25.0      | 13w1d | 10         |
| 05.0      | 7w3d | 10         | 12.0      | 9w3d  | 10         | 19.0      | 11w3d | 10         | 26.0      | 13w3d | 10         |
| 06.0      | 7w5d | 10         | 13.0      | 9w5d  | 10         | 20.0      | 11w5d | 10         | 27.0      | 13w5d | 10         |
| 07.0      | 8w0d | 10         | 14.0      | 10w0d | 10         | 21.0      | 12w0d | 10         |           |       |            |
| 08.0      | 8w2d | 10         | 15.0      | 10w2d | 10         | 22.0      | 12w2d | 10         |           |       |            |
| 09.0      | 8w4d | 10         | 16.0      | 10w4d | 10         | 23.0      | 12w4d | 10         |           |       |            |

**Osaka:**

Fetal Growth Chart Using the Ultrasonotomographic Technique, Keiichi Kurachi, Mineo Aoki, Department of Obstetrics and Gynecology, Osaka University Medical School Revision 3 (September 1983)

Table **BPD**, Osaka

| BPD<br>cm | MEAN  | MIN   | MAX   | BPD<br>cm | MEAN  | MIN   | MAX   | BPD<br>cm | MEAN  | MIN   | MAX   |
|-----------|-------|-------|-------|-----------|-------|-------|-------|-----------|-------|-------|-------|
| 1.33      | 10w0d | 9w4d  | 10w3d | 4.94      | 20w2d | 19w3d | 21w1d | 7.88      | 30w4d | 29w0d | 32w1d |
| 1.44      | 10w2d | 9w6d  | 10w5d | 5.03      | 20w4d | 19w5d | 21w3d | 7.95      | 30w6d | 29w2d | 32w3d |
| 1.55      | 10w4d | 10w0d | 11w0d | 5.12      | 20w6d | 20w0d | 21w5d | 8.02      | 31w1d | 29w4d | 32w5d |
| 1.66      | 10w6d | 10w2d | 11w2d | 5.21      | 21w1d | 20w1d | 22w0d | 8.08      | 31w3d | 29w6d | 33w0d |
| 1.77      | 11w1d | 10w4d | 11w4d | 5.30      | 21w3d | 20w3d | 22w2d | 8.15      | 31w5d | 30w1d | 33w3d |
| 1.88      | 11w3d | 10w6d | 11w6d | 5.39      | 21w5d | 20w5d | 22w4d | 8.21      | 32w0d | 30w3d | 33w5d |
| 1.99      | 11w5d | 11w1d | 12w2d | 5.48      | 22w0d | 21w0d | 22w6d | 8.27      | 32w2d | 30w4d | 34w0d |
| 2.09      | 12w0d | 11w3d | 12w3d | 5.57      | 22w2d | 21w2d | 23w2d | 8.34      | 32w4d | 30w6d | 34w3d |
| 2.20      | 12w2d | 11w5d | 12w6d | 5.66      | 22w4d | 21w4d | 23w4d | 8.40      | 32w6d | 31w1d | 34w5d |

|      |       |       |       |      |       |       |       |      |       |       |       |
|------|-------|-------|-------|------|-------|-------|-------|------|-------|-------|-------|
| 2.31 | 12w4d | 12w0d | 13w1d | 5.74 | 22w6d | 21w5d | 23w6d | 8.46 | 33w1d | 31w3d | 35w1d |
| 2.41 | 12w6d | 12w1d | 13w3d | 5.83 | 23w1d | 22w1d | 24w1d | 8.51 | 33w3d | 31w4d | 35w3d |
| 2.52 | 13w1d | 12w3d | 13w5d | 5.92 | 23w3d | 22w3d | 24w3d | 8.57 | 33w5d | 31w6d | 35w6d |
| 2.62 | 13w3d | 12w5d | 14w0d | 6.00 | 23w5d | 22w4d | 24w5d | 8.62 | 34w0d | 32w1d | 36w1d |
| 2.72 | 13w5d | 13w0d | 14w2d | 6.09 | 24w0d | 22w6d | 25w0d | 8.68 | 34w2d | 32w3d | 36w4d |
| 2.82 | 14w0d | 13w2d | 14w4d | 6.17 | 24w2d | 23w1d | 25w2d | 8.73 | 34w4d | 32w4d | 37w0d |
| 2.93 | 14w2d | 13w4d | 14w6d | 6.26 | 24w4d | 23w3d | 25w4d | 8.78 | 34w6d | 32w6d | 37w3d |
| 3.03 | 14w4d | 13w6d | 15w1d | 6.34 | 24w6d | 23w5d | 25w6d | 8.83 | 35w1d | 33w0d | 38w0d |
| 3.13 | 14w6d | 14w1d | 15w3d | 6.43 | 25w1d | 24w0d | 26w2d | 8.87 | 35w3d | 33w2d | 38w2d |
| 3.23 | 15w1d | 14w3d | 15w6d | 6.51 | 25w3d | 24w2d | 26w4d | 8.92 | 35w5d | 33w4d | 39w0d |
| 3.33 | 15w3d | 14w5d | 16w1d | 6.59 | 25w5d | 24w4d | 26w6d | 8.96 | 36w0d | 33w5d | 39w4d |
| 3.42 | 15w5d | 14w6d | 16w3d | 6.67 | 26w0d | 24w6d | 27w1d | 9.00 | 36w2d | 34w0d | 40w0d |
| 3.52 | 16w0d | 15w1d | 16w5d | 6.75 | 26w2d | 25w0d | 27w3d | 9.04 | 36w4d | 34w1d | 40w1d |
| 3.62 | 16w2d | 15w3d | 17w0d | 6.84 | 26w4d | 25w3d | 27w5d | 9.08 | 36w6d | 34w3d | 40w2d |
| 3.72 | 16w4d | 15w6d | 17w2d | 6.92 | 26w6d | 25w4d | 28w0d | 9.12 | 37w1d | 34w4d | 40w3d |
| 3.81 | 16w6d | 16w0d | 17w4d | 6.99 | 27w1d | 25w6d | 28w2d | 9.15 | 37w3d | 34w5d | 40w4d |
| 3.91 | 17w1d | 16w2d | 17w6d | 7.07 | 27w3d | 26w1d | 28w4d | 9.18 | 37w5d | 35w0d | 40w5d |
| 4.01 | 17w3d | 16w4d | 18w1d | 7.15 | 27w5d | 26w3d | 29w0d | 9.21 | 38w0d | 35w1d | 40w6d |
| 4.10 | 17w5d | 16w6d | 18w3d | 7.23 | 28w0d | 26w5d | 29w2d | 9.24 | 38w2d | 35w2d | 41w0d |
| 4.20 | 18w0d | 17w1d | 18w5d | 7.30 | 28w2d | 27w0d | 29w5d | 9.27 | 38w4d | 35w3d | 41w0d |
| 4.29 | 18w2d | 17w3d | 19w0d | 7.38 | 28w4d | 27w2d | 29w6d | 9.29 | 38w6d | 35w4d | 41w0d |
| 4.39 | 18w4d | 17w5d | 19w2d | 7.45 | 28w6d | 27w3d | 30w1d | 9.31 | 39w1d | 35w5d | 41w0d |
| 4.48 | 18w6d | 18w0d | 19w5d | 7.53 | 29w1d | 27w5d | 30w4d | 9.33 | 39w3d | 35w6d | 41w0d |
| 4.57 | 19w1d | 18w2d | 20w0d | 7.60 | 29w3d | 28w0d | 30w6d | 9.35 | 39w5d | 36w0d | 41w0d |
| 4.67 | 19w3d | 18w4d | 20w2d | 7.67 | 29w5d | 28w2d | 31w1d | 9.36 | 40w0d | 36w0d | 41w0d |
| 4.76 | 19w5d | 18w6d | 20w4d | 7.74 | 30w0d | 28w4d | 31w3d |      |       |       |       |
| 4.85 | 20w0d | 19w1d | 20w6d | 7.81 | 30w2d | 28w6d | 31w5d |      |       |       |       |

**Tokyo:**

Studies on Fetal Growth and Functional Developments, Takashi Okai, Department of Obstetrics and Gynecology, Faculty of Medicine, University of Tokyo

Table **BPD**, Tokyo

| BPD<br>cm | MA    | +/-<br>2SD | BPD<br>cm | MA    | +/-<br>2SD | BPD<br>cm | MA    | +/-<br>2SD | BPD<br>cm | MA    | +/-<br>2SD |
|-----------|-------|------------|-----------|-------|------------|-----------|-------|------------|-----------|-------|------------|
| 1.6       | 11w3d | 7          | 3.6       | 16w3d | 8          | 5.6       | 23w0d | 11         | 7.6       | 30w1d | 15         |
| 1.8       | 11w6d | 7          | 3.8       | 17w0d | 8          | 5.8       | 23w5d | 11         | 7.8       | 31w0d | 16         |
| 2         | 12w0d | 7          | 4         | 17w5d | 8          | 6         | 24w2d | 12         | 8         | 32w0d | 16         |
| 2.2       | 12w4d | 7          | 4.2       | 18w2d | 9          | 6.2       | 25w0d | 12         | 8.2       | 33w0d | 16         |
| 2.4       | 13w0d | 7          | 4.4       | 19w0d | 9          | 6.4       | 25w6d | 12         | 8.4       | 34w0d | 20         |
| 2.6       | 13w6d | 7          | 4.6       | 19w5d | 10         | 6.6       | 26w3d | 13         | 8.6       | 35w5d | 25         |
| 2.8       | 14w2d | 7          | 4.8       | 20w2d | 10         | 6.8       | 27w3d | 13         | 8.8       | 37w0d | 25         |
| 3         | 14w6d | 7          | 5         | 21w0d | 10         | 7         | 28w0d | 13         | 9         | 39w0d | 25         |
| 3.2       | 15w2d | 7          | 5.2       | 21w4d | 10         | 7.2       | 29w0d | 14         | 9.2       | 40w0d | 25         |
| 3.4       | 16w0d | 8          | 5.4       | 22w2d | 10         | 7.4       | 29w5d | 14         |           |       |            |

**China:**

Wu Zhongyu, "Ultrasound Diagnosis in Obstetrics and Gynecology", Tianjin Science and Technology Publisher, 1995

Table **BPD**, China

| BPD<br>cm | MA    | +/-<br>2SD | BPD<br>cm | MA    | +/-<br>2SD | BPD<br>cm | MA    | +/-<br>2SD | BPD<br>cm | MA    | +/-<br>2SD |
|-----------|-------|------------|-----------|-------|------------|-----------|-------|------------|-----------|-------|------------|
| 1.9       | 12w0d | 7          | 3.8       | 17w3d | 9          | 5.7       | 23w1d | 13         | 7.6       | 30w0d | 20         |
| 2         | 12w2d | 7          | 3.9       | 17w5d | 9          | 5.8       | 23w3d | 14         | 7.7       | 30w3d | 20         |
| 2.1       | 12w4d | 7          | 4         | 18w0d | 9          | 5.9       | 23w5d | 14         | 7.8       | 30w6d | 21         |
| 2.2       | 12w6d | 7          | 4.1       | 18w2d | 9          | 6         | 24w0d | 14         | 7.9       | 31w3d | 21         |
| 2.3       | 13w1d | 7          | 4.2       | 18w4d | 9          | 6.1       | 24w2d | 15         | 8         | 31w6d | 21         |
| 2.4       | 13w3d | 7          | 4.3       | 18w6d | 10         | 6.2       | 24w5d | 15         | 8.1       | 32w3d | 22         |
| 2.5       | 13w5d | 7          | 4.4       | 19w1d | 10         | 6.3       | 25w0d | 15         | 8.2       | 32w6d | 22         |
| 2.6       | 14w0d | 7          | 4.5       | 19w4d | 10         | 6.4       | 25w2d | 15         | 8.3       | 33w2d | 23         |
| 2.7       | 14w2d | 7          | 4.6       | 19w6d | 10         | 6.5       | 25w5d | 16         | 8.4       | 33w6d | 23         |
| 2.8       | 14w4d | 7          | 4.7       | 20w1d | 11         | 6.6       | 26w0d | 16         | 8.5       | 34w3d | 23         |
| 2.9       | 14w6d | 8          | 4.8       | 20w3d | 11         | 6.7       | 26w3d | 16         | 8.6       | 34w6d | 24         |
| 3         | 15w1d | 8          | 4.9       | 20w5d | 11         | 6.8       | 26w5d | 16         | 8.7       | 35w4d | 24         |
| 3.1       | 15w3d | 8          | 5         | 21w0d | 11         | 6.9       | 27w1d | 18         | 8.8       | 36w1d | 24         |
| 3.2       | 15w5d | 8          | 5.1       | 21w2d | 11         | 7         | 27w3d | 18         | 8.9       | 36w5d | 24         |
| 3.3       | 16w0d | 8          | 5.2       | 21w4d | 12         | 7.1       | 27w6d | 18         | 9         | 37w1d | 25         |
| 3.4       | 16w2d | 8          | 5.3       | 21w6d | 12         | 7.2       | 28w1d | 18         | 9.1       | 37w1d | 25         |
| 3.5       | 16w4d | 8          | 5.4       | 22w1d | 12         | 7.3       | 28w4d | 19         | 9.2       | 38w4d | 25         |
| 3.6       | 16w6d | 8          | 5.5       | 22w3d | 13         | 7.4       | 29w1d | 19         | 9.3       | 39w2d | 25         |
| 3.7       | 17w1d | 8          | 5.6       | 22w5d | 13         | 7.5       | 29w4d | 20         | 9.4       | 40w0d | 25         |

## 4.5. HC

### Hadlock:

Hadlock FP, Deter RL etc. "Estimation Fetal Age: Computer-Assisted Analysis of Multiple Fetal Growth Parameters." Radiology 152:497, 1984

$$MA(HC \text{ cm}) = 8.96 + 0.540 * (HC) + 0.0003 * (HC^3)$$

### Merz:

Merz E. Ultrasound in Gynecology and Obstetrics. Stuttgart and New York: Thieme Medical Publishers, Inc., 1991, p. 326

Table HC, Merz

| HC<br>mm | MA   | +/-<br>2SD | HC<br>mm | MA   | +/-<br>2SD | HC<br>mm | MA   | +/-<br>2SD | HC<br>mm | MA   | +/-<br>2SD |
|----------|------|------------|----------|------|------------|----------|------|------------|----------|------|------------|
| 72       | 12w1 | 9          | 146      | 17w2 | 12         | 220      | 23w2 | 15         | 294      | 30w5 | 16         |
| 74       | 12w2 | 11         | 148      | 17w4 | 12         | 222      | 23w4 | 15         | 296      | 30w6 | 17         |
| 76       | 12w3 | 10         | 150      | 17w4 | 13         | 224      | 23w4 | 15         | 298      | 31w1 | 16         |
| 78       | 12w4 | 10         | 152      | 17w6 | 12         | 226      | 23w6 | 15         | 300      | 31w3 | 17         |
| 80       | 12w5 | 10         | 154      | 17w6 | 13         | 228      | 24w0 | 16         | 302      | 31w4 | 17         |
| 82       | 12w6 | 10         | 156      | 18w1 | 12         | 230      | 24w1 | 16         | 304      | 31w6 | 17         |
| 84       | 12w6 | 11         | 158      | 18w1 | 13         | 232      | 24w3 | 15         | 306      | 32w1 | 17         |
| 86       | 13w1 | 10         | 160      | 18w3 | 12         | 234      | 24w4 | 15         | 308      | 32w2 | 17         |
| 88       | 13w1 | 11         | 162      | 18w4 | 12         | 236      | 24w4 | 15         | 310      | 32w4 | 17         |
| 90       | 13w2 | 11         | 164      | 18w5 | 12         | 238      | 24w6 | 16         | 312      | 32w6 | 17         |
| 92       | 13w4 | 10         | 166      | 18w6 | 12         | 240      | 25w1 | 15         | 314      | 33w1 | 17         |
| 94       | 13w4 | 11         | 168      | 19w0 | 13         | 242      | 25w2 | 16         | 316      | 33w3 | 17         |
| 96       | 13w5 | 10         | 170      | 19w1 | 12         | 244      | 25w4 | 15         | 318      | 33w4 | 17         |
| 98       | 13w6 | 11         | 172      | 19w2 | 13         | 246      | 25w5 | 16         | 320      | 33w6 | 18         |
| 100      | 14w0 | 10         | 174      | 19w3 | 12         | 248      | 25w6 | 16         | 322      | 34w1 | 17         |
| 102      | 14w1 | 12         | 176      | 19w4 | 13         | 250      | 26w0 | 16         | 324      | 34w3 | 18         |
| 104      | 14w2 | 11         | 178      | 19w6 | 13         | 252      | 26w1 | 16         | 326      | 34w5 | 18         |
| 106      | 14w3 | 11         | 180      | 19w6 | 15         | 254      | 26w3 | 15         | 328      | 34w6 | 18         |
| 108      | 14w4 | 11         | 182      | 20w1 | 13         | 256      | 26w4 | 16         | 330      | 35w1 | 18         |
| 110      | 14w5 | 11         | 184      | 20w1 | 15         | 258      | 26w6 | 15         | 332      | 35w4 | 18         |
| 112      | 14w6 | 11         | 186      | 20w3 | 13         | 260      | 27w0 | 16         | 334      | 35w6 | 18         |
| 114      | 15w0 | 11         | 188      | 20w4 | 13         | 262      | 27w1 | 16         | 336      | 36w1 | 18         |
| 116      | 15w1 | 11         | 190      | 20w5 | 13         | 264      | 27w3 | 15         | 338      | 36w3 | 18         |
| 118      | 15w2 | 11         | 192      | 20w6 | 15         | 266      | 27w4 | 16         | 340      | 36w4 | 19         |
| 120      | 15w3 | 11         | 194      | 21w1 | 13         | 268      | 27w6 | 15         | 342      | 36w6 | 19         |
| 122      | 15w4 | 12         | 196      | 21w1 | 15         | 270      | 28w1 | 16         | 344      | 37w1 | 19         |
| 124      | 15w5 | 12         | 198      | 21w3 | 13         | 272      | 28w2 | 16         | 346      | 37w4 | 18         |
| 126      | 15w6 | 11         | 200      | 21w4 | 15         | 274      | 28w4 | 16         | 348      | 37w6 | 19         |



|     |      |    |     |      |    |     |      |    |     |      |    |
|-----|------|----|-----|------|----|-----|------|----|-----|------|----|
| 128 | 16w0 | 12 | 202 | 21w5 | 15 | 276 | 28w5 | 16 | 350 | 38w1 | 21 |
| 130 | 16w1 | 12 | 204 | 21w6 | 15 | 278 | 28w6 | 17 | 352 | 38w4 | 19 |
| 132 | 16w2 | 12 | 206 | 22w1 | 15 | 280 | 29w1 | 16 | 354 | 38w6 | 19 |
| 134 | 16w3 | 12 | 208 | 22w1 | 15 | 282 | 29w2 | 16 | 356 | 39w1 | 19 |
| 136 | 16w4 | 12 | 210 | 22w3 | 15 | 284 | 29w4 | 17 | 358 | 39w4 | 19 |
| 138 | 16w5 | 12 | 212 | 22w3 | 15 | 286 | 29w6 | 16 | 360 | 39w6 | 19 |
| 140 | 16w6 | 12 | 214 | 22w5 | 15 | 288 | 30w0 | 16 | 362 | 40w1 | 19 |
| 142 | 17w0 | 12 | 216 | 22w6 | 15 | 290 | 30w1 | 17 | 364 | 40w4 | 19 |
| 144 | 17w1 | 12 | 218 | 23w1 | 15 | 292 | 30w4 | 16 |     |      |    |

## 4.6. AC

### Hadlock:

Hadlock FP, Deter RL etc. "Estimation Fetal Age: Computer-Assisted Analysis of Multiple Fetal Growth Parameters." Radiology 152:497, 1984

$$MA (AC \text{ cm}) = 8.14 + 0.753 * (AC) + 0.0036 * (AC^2)$$

### Merz:

Merz E. Ultrasound in Gynecology and Obstetrics. Stuttgart and New York: Thieme Medical Publishers, Inc., 1991, p. 326

Table AC, Merz

| AC mm | MA   | +/- 2SD | AC mm | MA   | +/- 2SD | AC mm | MA   | +/- 2SD | AC mm | MA   | +/- 2SD |
|-------|------|---------|-------|------|---------|-------|------|---------|-------|------|---------|
| 56    | 12w1 | 10      | 130   | 19w1 | 12      | 206   | 26w3 | 15      | 280   | 33w3 | 17      |
| 58    | 12w2 | 11      | 132   | 19w2 | 12      | 208   | 26w4 | 15      | 282   | 33w4 | 17      |
| 60    | 12w4 | 10      | 134   | 19w3 | 12      | 210   | 26w6 | 15      | 284   | 33w6 | 17      |
| 62    | 12w5 | 10      | 136   | 19w5 | 12      | 212   | 27w0 | 15      | 286   | 34w0 | 17      |
| 64    | 12w6 | 11      | 138   | 19w6 | 12      | 214   | 27w1 | 15      | 288   | 34w1 | 18      |
| 66    | 13w1 | 11      | 140   | 20w1 | 12      | 216   | 27w2 | 15      | 290   | 34w3 | 18      |
| 68    | 13w2 | 11      | 142   | 20w2 | 13      | 218   | 27w4 | 15      | 292   | 34w4 | 18      |
| 70    | 13w4 | 11      | 144   | 20w4 | 12      | 220   | 27w5 | 16      | 294   | 34w5 | 18      |
| 72    | 13w4 | 11      | 146   | 20w5 | 12      | 222   | 27w6 | 16      | 296   | 34w6 | 19      |
| 74    | 13w6 | 11      | 148   | 20w6 | 13      | 224   | 28w1 | 15      | 298   | 35w1 | 17      |
| 76    | 14w0 | 11      | 150   | 21w1 | 15      | 226   | 28w2 | 16      | 300   | 35w2 | 18      |
| 78    | 14w1 | 12      | 152   | 21w1 | 15      | 228   | 28w4 | 16      | 302   | 35w4 | 17      |
| 80    | 14w3 | 11      | 154   | 21w3 | 15      | 230   | 28w5 | 16      | 304   | 35w5 | 18      |
| 82    | 14w4 | 11      | 156   | 21w4 | 13      | 232   | 28w6 | 16      | 306   | 35w6 | 18      |
| 84    | 14w6 | 11      | 158   | 21w6 | 13      | 234   | 29w0 | 16      | 308   | 36w1 | 17      |
| 86    | 15w0 | 11      | 160   | 22w0 | 13      | 236   | 29w1 | 17      | 310   | 36w2 | 18      |
| 88    | 15w1 | 11      | 162   | 22w1 | 15      | 238   | 29w3 | 16      | 312   | 36w4 | 17      |
| 90    | 15w3 | 11      | 164   | 22w3 | 13      | 240   | 29w4 | 17      | 314   | 36w4 | 19      |

|     |      |    |     |      |    |     |      |    |     |      |    |
|-----|------|----|-----|------|----|-----|------|----|-----|------|----|
| 92  | 15w4 | 11 | 168 | 22w6 | 13 | 242 | 29w6 | 16 | 316 | 36w6 | 18 |
| 94  | 15w5 | 12 | 170 | 23w0 | 13 | 244 | 30w0 | 16 | 318 | 37w0 | 18 |
| 96  | 15w6 | 12 | 172 | 23w1 | 15 | 246 | 30w1 | 17 | 320 | 37w1 | 18 |
| 98  | 16w1 | 12 | 174 | 23w2 | 15 | 248 | 30w3 | 16 | 322 | 37w3 | 18 |
| 100 | 16w2 | 12 | 176 | 23w4 | 13 | 250 | 30w4 | 17 | 324 | 37w4 | 19 |
| 102 | 16w4 | 11 | 178 | 23w5 | 15 | 252 | 30w6 | 16 | 326 | 37w6 | 18 |
| 104 | 16w5 | 12 | 180 | 23w6 | 15 | 254 | 30w6 | 17 | 328 | 38w0 | 18 |
| 106 | 16w6 | 12 | 182 | 24w1 | 15 | 256 | 31w1 | 17 | 330 | 38w1 | 18 |
| 108 | 17w1 | 11 | 184 | 24w2 | 15 | 258 | 31w2 | 17 | 332 | 38w3 | 18 |
| 110 | 17w2 | 11 | 186 | 24w4 | 15 | 260 | 31w4 | 17 | 334 | 38w4 | 18 |
| 112 | 17w3 | 12 | 188 | 24w5 | 15 | 262 | 31w5 | 17 | 336 | 38w5 | 18 |
| 114 | 17w4 | 12 | 190 | 24w6 | 16 | 264 | 31w6 | 17 | 338 | 38w6 | 19 |
| 116 | 17w6 | 12 | 192 | 25w0 | 16 | 266 | 32w1 | 17 | 340 | 39w1 | 19 |
| 118 | 18w0 | 12 | 194 | 25w1 | 16 | 268 | 32w2 | 17 | 342 | 39w2 | 19 |
| 120 | 18w1 | 12 | 196 | 25w3 | 15 | 270 | 32w4 | 17 | 344 | 39w4 | 19 |
| 122 | 18w3 | 12 | 198 | 25w4 | 16 | 272 | 32w5 | 17 | 346 | 39w5 | 19 |
| 124 | 18w4 | 12 | 200 | 25w6 | 15 | 274 | 32w6 | 17 | 348 | 39w6 | 19 |
| 126 | 18w6 | 12 | 202 | 26w0 | 16 | 276 | 33w0 | 17 |     |      |    |
| 128 | 19w0 | 12 | 204 | 26w1 | 15 | 278 | 33w1 | 17 |     |      |    |

## 4.7. FL

### Hadlock:

Hadlock FP, Deter RL etc. "Estimation Fetal Age: Computer-Assisted Analysis of Multiple Fetal Growth Parameters." Radiology 152:497, 1984

$$MA \text{ (FL cm)} = 10.35 + 2.460 * (\text{FL}) + 0.170 * (\text{FL}^2)$$

### Merz:

Merz E. Ultrasound in Gynecology and Obstetrics. Stuttgart and New York: Thieme Medical Publishers, Inc., 1991, p. 326

Table FL, Merz

| FL mm | MA    | +/- 2SD | FL mm | MA    | +/- 2SD | FL mm | MA    | +/- 2SD | FL mm | MA    | +/- 2SD |
|-------|-------|---------|-------|-------|---------|-------|-------|---------|-------|-------|---------|
| 10    | 12w2d | 11      | 28    | 18w4d | 13      | 47    | 25w6d | 15      | 65    | 33w1d | 17      |
| 11    | 12w5d | 10      | 29    | 19w0d | 12      | 48    | 26w1d | 16      | 66    | 33w4d | 17      |
| 12    | 13w2d | 10      | 30    | 19w3d | 12      | 49    | 26w4d | 15      | 68    | 34w4d | 17      |
| 13    | 13w4d | 11      | 31    | 19w5d | 12      | 50    | 26w6d | 16      | 69    | 35w0d | 18      |
| 14    | 13w5d | 11      | 32    | 20w1d | 12      | 51    | 27w2d | 16      | 70    | 35w3d | 18      |
| 15    | 14w0d | 11      | 33    | 20w4d | 13      | 52    | 27w5d | 16      | 71    | 35w6d | 18      |
| 16    | 14w3d | 11      | 34    | 20w6d | 13      | 53    | 28w1d | 16      | 72    | 36w2d | 18      |
| 17    | 14w5d | 11      | 35    | 21w1d | 15      | 54    | 28w4d | 17      | 73    | 36w6d | 18      |

|    |       |    |    |       |    |    |       |    |    |       |    |
|----|-------|----|----|-------|----|----|-------|----|----|-------|----|
| 18 | 15w1d | 11 | 36 | 21w4d | 13 | 55 | 29w0d | 17 | 74 | 37w2d | 19 |
| 19 | 15w3d | 11 | 37 | 21w6d | 15 | 56 | 29w3d | 17 | 75 | 37w5d | 18 |
| 20 | 15w6d | 11 | 38 | 22w2d | 13 | 57 | 29w6d | 17 | 76 | 38w1d | 19 |
| 21 | 16w1d | 11 | 40 | 23w1d | 15 | 58 | 30w1d | 17 | 77 | 38w5d | 19 |
| 22 | 16w4d | 11 | 41 | 23w3d | 15 | 59 | 30w4d | 17 | 78 | 39w1d | 19 |
| 23 | 16w4d | 11 | 42 | 23w5d | 15 | 60 | 31w0d | 17 | 79 | 39w4d | 19 |
| 24 | 17w1d | 12 | 43 | 24w1d | 15 | 61 | 31w4d | 17 | 80 | 40w1d | 18 |
| 25 | 14w7d | 13 | 44 | 24w4d | 16 | 62 | 31w6d | 17 |    |       |    |
| 26 | 17w6d | 13 | 45 | 25w0d | 16 | 63 | 32w2d | 17 |    |       |    |
| 27 | 18w2d | 13 | 46 | 25w3d | 15 | 64 | 32w6d | 17 |    |       |    |

**Jeanty:**

Jeanty P, Rodesch F etc. "Estimation of Gestational Age from measurement of Fetal Long Bones." Journal of Ultrasound in Medicine 3:75, 1984

$$MA (FL \text{ mm}) = (9.5411757 + 0.2977451 * FL) + (0.0010388013 * FL^2)$$

**Tokyo:**

Studies on Fetal Growth and Functional Developments, Takashi Okai, Department of Obstetrics and Gynecology, Faculty of Medicine, University of Tokyo

Table FL, Tokyo

| FL cm | MA    | +/- 2SD | FL cm | MA    | +/- 2SD | FL cm | MA    | +/- 2SD | FL cm | MA    | +/- 2SD |
|-------|-------|---------|-------|-------|---------|-------|-------|---------|-------|-------|---------|
| 0.8   | 12w3d | 10      | 2.6   | 17w6d | 10      | 4.4   | 25w2d | 25      | 6.2   | 34w0d | 42      |
| 1     | 13w0d | 10      | 2.8   | 18w4d | 14      | 4.6   | 26w0d | 25      | 6.4   | 35w0d | 46      |
| 1.2   | 13w4d | 10      | 3     | 19w2d | 17      | 4.8   | 27w0d | 25      | 6.6   | 36w0d | 50      |
| 1.4   | 14w1d | 10      | 3.2   | 20w5d | 17      | 5     | 28w0d | 25      | 6.8   | 38w0d | 57      |
| 1.6   | 14w5d | 10      | 3.4   | 21w5d | 18      | 5.2   | 29w0d | 30      | 7     | 40w0d | 64      |
| 1.8   | 15w2d | 10      | 3.6   | 22w3d | 19      | 5.4   | 29w5d | 30      | 7.2   | 40w2d | 64      |
| 2     | 16w0d | 10      | 3.8   | 23w0d | 21      | 5.6   | 30w2d | 30      |       |       |         |
| 2.2   | 16w4d | 10      | 4     | 24w0d | 22      | 5.8   | 31w3d | 32      |       |       |         |
| 2.4   | 17w1d | 10      | 4.2   | 24w5d | 24      | 6     | 33w0d | 38      |       |       |         |

**China:**

Wu Zhongyu, "Ultrasound Diagnosis in Obstetrics and Gynecology", Tianjin Science and Technology Publisher, 1995

Table FL, China

| FL cm | MA    | +/- 2SD | FL cm | MA    | +/- 2SD | FL cm | MA    | +/- 2SD | FL cm | MA    | +/- 2SD |
|-------|-------|---------|-------|-------|---------|-------|-------|---------|-------|-------|---------|
| 0.6   | 12w4d | 7       | 2.4   | 18w0d | 9       | 4.2   | 24w0d | 16      | 6     | 33w0d | 18      |
| 0.7   | 12w5d | 7       | 2.5   | 18w2d | 9       | 4.3   | 24w3d | 16      | 6.1   | 33w3d | 18      |

|     |       |   |     |       |    |     |       |    |     |       |    |
|-----|-------|---|-----|-------|----|-----|-------|----|-----|-------|----|
| 0.8 | 13w0d | 8 | 2.6 | 18w4d | 10 | 4.4 | 24w6d | 16 | 6.2 | 34w0d | 18 |
| 0.9 | 13w2d | 8 | 2.7 | 18w6d | 10 | 4.5 | 25w2d | 16 | 6.3 | 34w3d | 19 |
| 1   | 13w5d | 8 | 2.8 | 19w2d | 11 | 4.6 | 25w6d | 16 | 6.4 | 35w0d | 20 |
| 1.1 | 14w0d | 8 | 2.9 | 19w4d | 11 | 4.7 | 26w3d | 16 | 6.5 | 35w3d | 20 |
| 1.2 | 14w2d | 8 | 3   | 19w6d | 12 | 4.8 | 26w6d | 16 | 6.6 | 35w6d | 20 |
| 1.3 | 14w4d | 8 | 3.1 | 20w1d | 13 | 4.9 | 27w4d | 17 | 6.7 | 36w3d | 20 |
| 1.4 | 14w6d | 8 | 3.2 | 20w3d | 13 | 5   | 27w6d | 17 | 6.8 | 37w0d | 21 |
| 1.5 | 15w1d | 8 | 3.3 | 20w5d | 14 | 5.1 | 28w3d | 17 | 6.9 | 37w3d | 22 |
| 1.6 | 15w3d | 8 | 3.4 | 21w1d | 14 | 5.2 | 28w6d | 17 | 7   | 38w0d | 23 |
| 1.7 | 15w5d | 8 | 3.5 | 21w3d | 15 | 5.3 | 29w3d | 17 | 7.1 | 38w3d | 23 |
| 1.8 | 16w0d | 8 | 3.6 | 21w6d | 15 | 5.4 | 29w6d | 17 | 7.2 | 38w6d | 23 |
| 1.9 | 16w3d | 8 | 3.7 | 22w2d | 15 | 5.5 | 30w3d | 17 | 7.3 | 39w3d | 23 |
| 2   | 16w5d | 8 | 3.8 | 22w4d | 15 | 5.6 | 30w6d | 17 | 7.4 | 39w6d | 23 |
| 2.1 | 17w0d | 8 | 3.9 | 23w0d | 15 | 5.7 | 31w3d | 17 | 7.5 | 40w2d | 23 |
| 2.2 | 17w2d | 8 | 4   | 23w2d | 16 | 5.8 | 31w6d | 18 |     |       |    |
| 2.3 | 17w4d | 8 | 4.1 | 23w4d | 16 | 5.9 | 32w3d | 18 |     |       |    |

**Osaka:**

Osaka University (2002/April/08)

Table FL, Osaka

| FL<br>cm | Mean  | Min   | Max   | FL<br>cm | Mean  | Min   | Max   | FL<br>cm | Mean  | Min   | Max   |
|----------|-------|-------|-------|----------|-------|-------|-------|----------|-------|-------|-------|
| 0.94     | 13w0d | 12w3d | 13w4d | 3.61     | 22w1d | 21w1d | 23w1d | 5.69     | 31w2d | 29w6d | 32w5d |
| 1.03     | 13w2d | 12w5d | 13w6d | 3.68     | 22w3d | 21w3d | 23w3d | 5.74     | 31w4d | 30w1d | 33w0d |
| 1.12     | 13w4d | 12w6d | 14w1d | 3.75     | 22w5d | 21w5d | 23w4d | 5.80     | 31w6d | 30w2d | 33w3d |
| 1.21     | 13w6d | 13w1d | 14w3d | 3.83     | 23w0d | 22w0d | 24w0d | 5.85     | 32w1d | 30w4d | 33w5d |
| 1.30     | 14w1d | 13w3d | 14w5d | 3.90     | 23w2d | 22w2d | 24w2d | 5.90     | 32w3d | 30w6d | 34w0d |
| 1.39     | 14w3d | 13w5d | 15w1d | 3.97     | 23w4d | 22w4d | 24w4d | 5.96     | 32w5d | 31w1d | 34w2d |
| 1.48     | 14w5d | 14w0d | 15w3d | 4.04     | 23w6d | 22w6d | 24w6d | 6.01     | 33w0d | 31w3d | 34w4d |
| 1.57     | 15w0d | 14w2d | 15w5d | 4.11     | 24w1d | 23w0d | 25w1d | 6.06     | 33w2d | 31w5d | 34w6d |
| 1.66     | 15w2d | 14w4d | 16w0d | 4.18     | 24w3d | 23w2d | 25w3d | 6.11     | 33w4d | 32w0d | 35w1d |
| 1.75     | 15w4d | 14w6d | 16w2d | 4.25     | 24w5d | 23w4d | 25w5d | 6.16     | 33w6d | 32w1d | 35w3d |
| 1.83     | 15w6d | 15w1d | 16w4d | 4.32     | 25w0d | 23w6d | 26w0d | 6.21     | 34w1d | 32w3d | 35w6d |
| 1.92     | 16w1d | 15w3d | 16w6d | 4.39     | 25w2d | 24w1d | 26w3d | 6.26     | 34w3d | 32w5d | 36w1d |
| 2.01     | 16w3d | 15w4d | 17w1d | 4.45     | 25w4d | 24w3d | 26w4d | 6.31     | 34w5d | 33w0d | 36w3d |
| 2.09     | 16w5d | 15w6d | 17w3d | 4.52     | 25w6d | 24w5d | 27w0d | 6.36     | 35w0d | 33w2d | 36w6d |

|      |       |       |       |      |       |       |       |      |       |       |       |
|------|-------|-------|-------|------|-------|-------|-------|------|-------|-------|-------|
| 2.18 | 17w0d | 16w1d | 17w5d | 4.59 | 26w1d | 25w0d | 27w2d | 6.41 | 35w2d | 33w4d | 37w1d |
| 2.26 | 17w2d | 16w3d | 18w0d | 4.65 | 26w3d | 25w2d | 27w4d | 6.46 | 35w4d | 33w6d | 37w3d |
| 2.34 | 17w4d | 16w5d | 18w2d | 4.72 | 26w5d | 25w4d | 27w6d | 6.50 | 35w6d | 34w0d | 37w5d |
| 2.43 | 17w6d | 17w0d | 18w4d | 4.78 | 27w0d | 25w5d | 28w1d | 6.55 | 36w1d | 34w2d | 38w0d |
| 2.51 | 18w1d | 17w2d | 18w6d | 4.85 | 27w2d | 26w0d | 28w3d | 6.60 | 36w3d | 34w4d | 38w3d |
| 2.59 | 18w3d | 17w4d | 19w1d | 4.91 | 27w4d | 26w2d | 28w5d | 6.64 | 36w5d | 34w6d | 38w5d |
| 2.67 | 18w5d | 17w6d | 19w3d | 4.97 | 27w6d | 26w4d | 29w0d | 6.69 | 37w0d | 35w0d | 39w1d |
| 2.75 | 19w0d | 18w1d | 19w6d | 5.04 | 28w1d | 26w6d | 29w3d | 6.73 | 37w2d | 35w2d | 39w3d |
| 2.83 | 19w2d | 18w3d | 20w1d | 5.10 | 28w3d | 27w1d | 29w5d | 6.77 | 37w4d | 35w4d | 39w5d |
| 2.91 | 19w4d | 18w5d | 20w3d | 5.16 | 28w5d | 27w3d | 30w0d | 6.82 | 37w6d | 35w6d | 40w0d |
| 2.99 | 19w6d | 19w0d | 20w5d | 5.22 | 29w0d | 27w5d | 30w2d | 6.86 | 38w1d | 36w1d | 40w1d |
| 3.07 | 20w1d | 19w2d | 21w0d | 5.28 | 29w2d | 27w6d | 30w4d | 6.90 | 38w3d | 36w2d | 40w2d |
| 3.15 | 20w3d | 19w4d | 21w2d | 5.34 | 29w4d | 28w1d | 30w6d | 6.94 | 38w5d | 36w4d | 40w3d |
| 3.23 | 20w5d | 19w6d | 21w4d | 5.40 | 29w6d | 28w3d | 31w1d | 6.98 | 39w0d | 36w6d | 40w4d |
| 3.30 | 21w0d | 20w0d | 21w6d | 5.46 | 30w1d | 28w5d | 31w4d | 7.02 | 39w2d | 37w1d | 40w5d |
| 3.38 | 21w2d | 20w2d | 22w1d | 5.52 | 30w3d | 29w0d | 31w6d | 7.06 | 39w4d | 37w2d | 40w6d |
| 3.46 | 21w4d | 20w4d | 22w3d | 5.57 | 30w5d | 29w2d | 32w1d | 7.10 | 39w6d | 37w4d | 41w0d |
| 3.53 | 21w6d | 20w6d | 22w5d | 5.63 | 31w0d | 29w4d | 32w3d | 7.12 | 40w0d | 37w5d | 41w0d |

## 4.8. FTA

### Osaka:

Osaka University (2002/April/08)

Table FTA, Osaka

| FTA<br>cm <sup>2</sup> | MEAN  | MIN   | MAX   | FTA<br>cm <sup>2</sup> | MEAN  | MIN   | MAX   | FTA<br>cm <sup>2</sup> | MEAN  | MIN   | MAX   |
|------------------------|-------|-------|-------|------------------------|-------|-------|-------|------------------------|-------|-------|-------|
| 5.6                    | 14w0d | 13w2d | 14w5d | 26.4                   | 22w6d | 21w5d | 23w6d | 57.2                   | 31w5d | 29w6d | 33w3d |
| 6.0                    | 14w2d | 13w4d | 14w6d | 27.2                   | 23w1d | 22w0d | 24w1d | 58.3                   | 32w0d | 30w1d | 33w5d |
| 6.5                    | 14w4d | 13w6d | 15w2d | 28.1                   | 23w3d | 22w1d | 24w3d | 59.4                   | 32w2d | 30w3d | 34w0d |
| 7.1                    | 14w6d | 14w1d | 15w4d | 29.0                   | 23w5d | 22w3d | 24w6d | 60.4                   | 32w4d | 30w5d | 34w2d |
| 7.6                    | 15w1d | 14w2d | 15w6d | 29.9                   | 24w0d | 22w5d | 25w1d | 61.5                   | 32w6d | 31w0d | 34w5d |
| 8.1                    | 15w3d | 14w4d | 16w1d | 30.8                   | 24w2d | 23w0d | 25w3d | 62.6                   | 33w1d | 31w1d | 35w0d |

|      |       |       |       |      |       |       |       |      |       |       |       |
|------|-------|-------|-------|------|-------|-------|-------|------|-------|-------|-------|
| 8.7  | 15w5d | 14w6d | 16w3d | 31.7 | 24w4d | 23w2d | 25w5d | 63.7 | 33w3d | 31w3d | 35w2d |
| 9.2  | 16w0d | 15w1d | 16w5d | 32.6 | 24w6d | 23w4d | 26w0d | 64.7 | 33w5d | 31w5d | 35w4d |
| 9.8  | 16w2d | 15w3d | 17w0d | 33.6 | 25w1d | 23w6d | 26w2d | 65.8 | 34w0d | 32w0d | 36w0d |
| 10.4 | 16w4d | 15w5d | 17w2d | 34.5 | 25w3d | 24w1d | 26w5d | 66.9 | 34w2d | 32w1d | 36w2d |
| 11.0 | 16w6d | 16w0d | 17w5d | 35.5 | 25w5d | 24w2d | 26w6d | 67.9 | 34w4d | 32w3d | 36w5d |
| 11.6 | 17w1d | 16w2d | 17w6d | 36.5 | 26w0d | 24w4d | 27w2d | 69.0 | 34w6d | 32w5d | 37w0d |
| 12.2 | 17w3d | 16w3d | 18w2d | 37.4 | 26w2d | 24w6d | 27w4d | 70.1 | 35w1d | 33w0d | 37w2d |
| 12.8 | 17w5d | 16w5d | 18w4d | 38.4 | 26w4d | 25w1d | 27w6d | 71.1 | 35w3d | 33w1d | 37w5d |
| 13.5 | 18w0d | 17w0d | 18w6d | 39.4 | 26w6d | 25w3d | 28w1d | 72.2 | 35w5d | 33w3d | 38w0d |
| 14.1 | 18w2d | 17w2d | 19w1d | 40.4 | 27w1d | 25w5d | 28w3d | 73.2 | 36w0d | 33w5d | 38w3d |
| 14.8 | 18w4d | 17w4d | 19w3d | 41.4 | 27w3d | 26w0d | 28w5d | 74.2 | 36w2d | 33w6d | 38w5d |
| 15.5 | 18w6d | 17w6d | 19w5d | 42.4 | 27w5d | 26w2d | 29w1d | 75.2 | 36w4d | 34w1d | 39w1d |
| 16.2 | 19w1d | 18w1d | 20w0d | 43.4 | 28w0d | 26w3d | 29w2d | 76.2 | 36w6d | 34w3d | 39w3d |
| 16.9 | 19w3d | 18w3d | 20w2d | 44.5 | 28w2d | 26w5d | 29w5d | 77.3 | 37w1d | 34w4d | 39w6d |
| 17.6 | 19w5d | 18w4d | 20w4d | 45.5 | 28w4d | 27w0d | 30w0d | 78.2 | 37w3d | 34w6d | 40w0d |
| 18.4 | 20w0d | 19w0d | 20w6d | 46.6 | 28w6d | 27w2d | 30w2d | 79.2 | 37w5d | 35w0d | 40w1d |
| 19.1 | 20w2d | 19w1d | 21w1d | 47.6 | 29w1d | 27w4d | 30w4d | 80.2 | 38w0d | 35w2d | 40w2d |
| 19.9 | 20w4d | 19w3d | 21w4d | 48.7 | 29w3d | 27w6d | 30w6d | 81.1 | 38w2d | 35w3d | 40w3d |
| 20.6 | 20w6d | 19w5d | 21w6d | 49.7 | 29w5d | 28w1d | 31w1d | 82.1 | 38w4d | 35w5d | 40w4d |
| 21.4 | 21w1d | 20w0d | 22w1d | 50.8 | 30w0d | 28w3d | 31w3d | 83.0 | 38w6d | 36w0d | 40w5d |
| 22.2 | 21w3d | 20w2d | 22w3d | 51.8 | 30w2d | 28w4d | 31w6d | 83.9 | 39w1d | 36w1d | 40w6d |
| 23.0 | 21w5d | 20w4d | 22w5d | 52.9 | 30w4d | 28w6d | 32w1d | 84.8 | 39w3d | 36w3d | 41w0d |
| 23.8 | 22w0d | 20w6d | 23w0d | 54.0 | 30w6d | 29w1d | 32w3d | 85.7 | 39w5d | 36w4d | 41w0d |
| 24.7 | 22w2d | 21w1d | 23w2d | 55.0 | 31w1d | 29w3d | 32w5d | 86.6 | 40w0d | 36w6d | 41w0d |
| 25.5 | 22w4d | 21w3d | 23w4d | 56.1 | 31w3d | 29w5d | 33w0d |      |       |       |       |

## 4.9. HUM

### Jeanty:

Jeanty P, Rodesch F etc. "Estimation of Gestational Age from measurement of Fetal Long Bones."  
Journal of Ultrasound in Medicine 3:75, 1984

$$\text{MA (HUM mm)} = 9.6519438 + (0.26200391 * \text{HUM}) + (0.0026105367 * \text{HUM}^2)$$

## 4.10. CER

### Goldstein:

$$MA \text{ (CER mm)} = 6.329 + 4.807 * (\text{CER}/10) + 1.484 * (\text{CER}/10)^2 - 0.2474 * (\text{CER}/10)^3$$

## 4.11. THD

### Hansmann:

$$MA \text{ (THD mm)} = 6.963496 + 3.829853 * (\text{THD}/10) - 0.443065 * (\text{THD}/10)^2 + 0.1010238 * (\text{THD}/10)^3 - 0.0099702 * (\text{THD}/10)^4 + 0.0003773 * (\text{THD}/10)^5$$

## 4.12. Estimated Fetal Weight

Merz E, Werner G. & Ilan E. T., 1991, Ultrasound in Gynecology and Obstetrics Textbook and Atlas 312, 326-336.

Hansmann M, Hackelöer B-J, Staudach A, Ultraschalldiagnostik in Geburtshilfe und Gynäkologie 1995.

Campbell S, Wilkin D. "Ultrasonic Measurement of Fetal Abdomen Circumference in the Estimation of Fetal Weight." Br J Obstetrics and Gynecology September 82 (9):689-697, 1975.

Hadlock F, Harrist R, et al. Estimation of fetal weight with the use of head, body, and femur measurement – a prospective study. American Journal of Obstetrics and Gynecology February 1, 151 (3): 333-337, 1985.

Shepard M, Richards V, Berkowitz R, Warsof S, Hobbins J. An Evaluation of Two Equations for Predicting Fetal Weight by Ultrasound. American Journal of Obstetrics and Gynecology January 142 (1): 47-54, 1982.

Fetal Growth Chart Using the Ultrasonotomographic Technique, Keiichi Kurachi, Mineo Aoki, Department of Obstetrics and Gynecology, Osaka University Medical School Revision 3 (September 1983)

Studies on Fetal Growth and Functional Developments, Takashi Okai, Department of Obstetrics and Gynecology, Faculty of Medicine, University of Tokyo

P/N: 01.54.458118

MPN: 01.54.458118011



**EDAN INSTRUMENTS, INC.**

#15 Jinhui Road, Jinsha Community, Kengzi Sub-District  
Pingshan District, 518122 Shenzhen, P.R.China

Email: [info@edan.com.cn](mailto:info@edan.com.cn)

TEL: +86-755-2689 8326 FAX: +86-755-2689 8330

Website: [www.edan.com.cn](http://www.edan.com.cn)

**EC REPRESENTATIVE**

Shanghai International Holding Corp. GmbH

Eiffestrasse 80, 20537 Hamburg Germany

TEL: +49-40-2513175

E-mail: [shholding@hotmail.com](mailto:shholding@hotmail.com)